

SPP Board of Directors Approved Appendix A projects January 26, 2010

| NTC ID | UID | PID | Project Type | Project Description/Comments | Cost Estimate | Facility Owner | In-Service Date | 2009 STEP Date | 2009 STEP BOD Action | Latest Letter of notification to construct issue date | From Bus Name | To Bus Name | Circuit |
|------------------|-------|-------|---------------------------------|--|---------------|----------------|-----------------|----------------|----------------------|---|--|---|---------|
| Year 2010 | | | | | | | | | | | | | |
| 20000 | 10294 | 229 | regional reliability | Reconductor 5.14 mile Bentonville 279th St. - East Centerton 161 kv with 1590 conductor. | \$5,017,000 | AEP | 06/01/10 | M | | 02/13/08 | Bentonville 279th Street 161 kv | East Centerton 161 kv | 1 |
| 20016 | 10440 | 343 | regional reliability | Replace 69 kv switches at Winnboro and reset CT ratios and relay settings. | \$90,000 | AEP | 08/01/10 | M | | 01/16/09 | Winnboro 69 kv | Magdolia Tap 69 kv | 1 |
| 20016 | 10443 | 346 | regional reliability | Replace Qultman 69 kv bus, switches and jumpers, Change CT and relay settings. | \$185,000 | AEP | 06/01/10 | M | | 01/16/09 | Forest Hills 69 kv | Qultman 69 kv | 1 |
| | 11185 | 893 | zonal - sponsored | Restore existing 9.2 mile radial de-energized 138 kv line to service. Build 138-4.16 kv station at Enogex Wilberton. | \$1,456,000 | AEP | 07/01/10 | M | | | Lone Oak 138 kv | EnoGex Wilberton 138 kv | 1 |
| | 11186 | 894 | zonal - sponsored | Build new 0.6 mile double circuit tap from the existing Perdue - Lake Hawkins 138 kv line to a new 138 kv Excon - Mobil Hawkins switching station. | \$3,550,000 | AEP | 12/01/10 | M | | | Exxon-Mobil Hawkins 138 kv | Perdue 138 kv | 1 |
| | 11187 | 894 | zonal - sponsored | Build new 0.6 mile double circuit tap from the existing Perdue - Lake Hawkins 138 kv line to a new 138 kv Excon - Mobil Hawkins switching station. | \$3,550,000 | AEP | 12/01/10 | M | | | Exxon-Mobil Hawkins 138 kv | Lake Hawkins 138 kv | 1 |
| 20016 | 10652 | 507 | transmission service | Rebuild 3.24 miles of 1272 AAC with 2156 ACSR. Replace 3 138 kv switches, breaker jumpers, and reset CTs at Arsenal Hill. Replace 2 138 kv switches and jumpers at Fort Humburg. | \$5,428,300 | AEP | 06/01/10 | M | | 01/16/09 | Arsenal Hill 138 kv | Fort Humburg 138 kv | 1 |
| 20016 | 50155 | 30147 | transmission service | Replace auto and 69 kv breaker and switches. | \$3,005,700 | AEP | 06/01/10 | M | | 01/16/09 | Arsenal Hill 138 kv | Arsenal Hill 69 kv | 2 |
| 20016 | 50154 | 30146 | transmission service | Replace auto and 69 kv breaker and switches. | \$3,005,700 | AEP | 06/01/10 | M | | 01/16/09 | Arsenal Hill 138 kv | Arsenal Hill 69 kv | 1 |
| 20016 | 50161 | 30153 | transmission service | Replace four (4) switches and upgrading bus work. | \$200,000 | AEP | 06/01/10 | M | | 01/16/09 | Lonewood 345 kv | Lonewood 138 kv | 1 |
| | 10662 | 657 | regional reliability | Replace (3) 600 A switches with 1200 A switches. | \$150,000 | AEP | | 06/01/10 | NTC | | Pryor Junction 115 kv | Pryor Junction 69 kv | 1 |
| 19959 | 10375 | 289 | transmission service | Replace wave trap at Clinton City Substation. | \$135,400 | AEP | 06/01/10 | M | | 10/17/06 | Clinton City 69 kv | Foss Tap 69 kv | 1 |
| 20000 | 10380 | 293 | regional reliability | Replace Mineola 2 Switches & Breaker | \$338,000 | AEP | 06/01/10 | M | | 02/13/08 | North Mineola 69 kv | Mineola 69 kv | 1 |
| 20016 | 10445 | 348 | regional reliability | Build new 24 mile Turk - SE Texarkana 138 kv line and add SE Texarkana 138 kv terminal. | \$224,000 | AEP | 08/01/10 | M | | | Turk 138 kv | SE Texarkana 138 kv | 1 |
| 20027 | 10297 | 232 | Generation Interconnect | Build new 24 mile Turk - Sugar Hill 138 kv line and add Sugar Hill 138 kv terminal. | \$18,427,000 | AEP | 12/31/10 | M | | | Turk 138 kv | Sugar Hill 138 kv | 1 |
| 19953 | 10381 | 295 | transmission service | AEPW to reconductor 1.09 miles of 795 ACSR with 1590 ACSR. (Also, Westar to rebuild 3.93 miles of 795 ACSR with 1590 ACSR.) These ratings are just for the AEP facilities. | \$1,008,000 | AEP | 06/01/10 | M | | 06/26/07 | Coffeyville T. 138 kv | Dearing 138 kv | 1 |
| 20000 | 10383 | 297 | regional reliability | Reconductor Qultman - Westwood 69 kv 3.91 miles of 2/0 with 795 ACSR | \$3,827,000 | AEP | 06/01/10 | M | | 02/13/08 | Qultman 69 kv | Westwood 69 kv | 1 |
| 20016 | 10382 | 296 | transmission service | Rebuild/reconductor 5.17 mile Dvess - Elm Springs 161 kv with 2156 ACSR. | \$6,252,000 | AEP | 06/01/10 | M | | 01/16/09 | Dvess 161 kv | Elm Springs 161 kv | 1 |
| 20016 | 10445 | 348 | regional reliability | Replace 161 kv breaker, switches and CTs at Dvess. | \$224,000 | AEP | 08/01/10 | M | | 01/16/09 | Dvess 161 kv | Trotwood 161 kv | 1 |
| 20027 | 10784 | 613 | regional reliability | Replace switch at Diana for higher winter rating of 287/316 MVA. Summer rating unchanged. | \$1,000,000 | AEP | 12/01/10 | M | | | Diana 138 kv | Lone Star South 138 kv | 1 |
| 20027 | 10378 | 292 | regional reliability | Reconductor 2.66 mile Greggton - Lake Lamond 69 kv with 1272 ACSR. | \$4,047,000 | AEP | 06/01/10 | M | | 01/27/09 | Greggton 69 kv | Lake Lamond 69 kv | 1 |
| 20027 | 10617 | 480 | regional reliability | Build new 4 mile AEP Snyder - WFEC Snyder 138 kv. WFEC to connect AEP Snyder to WFEC Snyder. AEP to provide 138 kv terminal at AEP Snyder. | \$800,000 | AEP | 12/31/10 | M | | 01/27/09 | AEP Snyder 138 kv | WFEC Snyder 138 kv | 1 |
| | 11011 | 767 | regional reliability | Convert 17 mile Canadian River - McAlester City line from 69 kv to 138 kv. | \$17,000,000 | AEP | 06/01/10 | NTC | | | Canadian River 138 kv | McAlester City 138 kv | 1 |
| | 11012 | 767 | regional reliability | Tap Pittsburg - Muskogee 345 kv about 33 miles north of the Pittsburg station and step down to 138 kv with a 450 MVA auto. | \$8,500,000 | AEP | 06/01/10 | NTC | | | Canadian River 138 kv | McAlester City 138 kv | 1 |
| | 11183 | 767 | regional reliability | Rebuild McAlester City Tap, double circuiting existing line, eliminate the 'T' at McAlester City North Tap. | \$2,900,000 | AEP | 06/01/10 | NTC | | | McAlester City 138 kv | Dustin 138 kv | 1 |
| | 11184 | 767 | regional reliability | Rebuild McAlester City Tap, double circuiting existing line, eliminate the 'T' at McAlester City North Tap. | \$2,900,000 | AEP | 06/01/10 | NTC | | | McAlester City 138 kv | McAlester City North Tap 138 kv | 1 |
| | 50286 | 30248 | regional reliability - non OATT | Install 2 Blocks of 14.4 Mvar | \$1,166,400 | CRE | 06/01/10 | NTC | | | CR - Midland 138 kv | | |
| | 50287 | 30249 | regional reliability - non OATT | Install 2 Blocks of 7.2 Mvar | \$583,200 | CRE | 06/01/10 | NTC | | | CR - Salem | | |
| 20011 | 10271 | 212 | regional reliability | Reconductor 3 mile 69 kv line from 336.4 kcmil ACSR to 477 kcmil ACSR/TW | \$1,485,000 | CUS | 06/01/10 | M | | 02/13/08 | Norton 69 kv | Neergard 69 kv | 1 |
| | 10436 | 339 | zonal - sponsored | Step-Up Transformer for new SWPS #2 (DNR) | \$3,200,000 | CUS | 10/01/10 | M | | | Southwest 161 kv | Southwest 2 20 kv | 1 |
| | 10275 | 216 | regional reliability - non OATT | Rayburn Project - Build new 10 mile Ben Wheeler - Barton Chapel 138 kv. | | DETEC | 12/31/10 | M | | | Ben Wheeler (Wood County EC) 138 kv | Barton's Chapel (Rayburn County) 138 kv | 1 |
| 20010 | 50084 | 30078 | Zonal Reliability | Install (3) 22 Mvar capacitor banks for a total of 66 Mvar at Riverside Sub #438. | \$2,600,000 | EDE | 12/01/10 | M | | 02/13/08 | SUB 438 - Riverside 161 kv | | |
| 20049 | 10495 | 382 | regional reliability | Change CT setting on Breaker #6973 at Baxter #271 to 800/5 ratio. | \$50,000 | EDE | 06/01/10 | M | | 09/18/09 | SUB 404 - Hockerville 69 kv | SUB 271 - Baxter Springs West 69 kv | 1 |
| 20036 | 10547 | 421 | regional reliability | Change CT ratio on breaker #6936 at Aurora Substation 124. | \$5,000 | EDE | 06/01/10 | M | | 01/27/09 | SUB 124 - Aurora H. T. 69 kv | SUB 152 - Monett H. T. 69 kv | 1 |
| 19969 | 10435 | 338 | transmission service | Rebuild 1.7 mile Neosho South Jct. - Neosho SPA 161 kv from 336 ACSR to 795 ACSR and replace terminal equipment | \$1,215,000 | EDE | 06/01/10 | M | | 09/22/06 | SUB 184 - Neosho South Junction 161 kv | Neosho (SW PA) 161 kv | 1 |
| 20049 | 10641 | 496 | regional reliability | Replace 600 amp disconnect switches with a minimum 1,200 amp units and replace leads on Breaker #6965 at Sub #64 and #6932 at Sub #145. | \$55,000 | EDE | 06/01/10 | 06/01/15 | | 09/18/09 | SUB 145 - Joplin West 77H 69 kv | SUB 64 - Joplin 10TH ST. 69 kv | 1 |
| 20053 | 50225 | 30221 | regional reliability | Add 12 Mvar cap bank at Ralph Green | \$486,000 | GMO | 06/01/10 | M | | 09/18/09 | Ralph Green 69 kv | | |
| 20034 | 10768 | 601 | regional reliability | Replace wavetraps at Longview and Grandview East on the Grandview - Longview 161kv line. | \$50,000 | GMO | 06/01/10 | M | | 01/27/09 | Grandview East 161 kv | Longview 161 kv | 1 |
| 20034 | 10816 | 628 | regional reliability | Replace wavetraps at Platte City. | \$50,000 | GMO | 12/01/10 | M | | 01/27/09 | Platte City 161 kv | Smithville 161 kv | 1 |
| 20034 | 10832 | 635 | regional reliability | Build a new Edmond 161/69/34.5 kv substation between the Cook and Lake Road 161 kv substations that will pick up the loads supplied by the Lake Road 161/34.5 kv source. | \$5,405,930 | GMO | 07/01/10 | M | | 01/27/09 | Cook 161 kv | Lake Road 161 kv | 1 |
| 20053 | 50226 | 30222 | regional reliability | Reset the overcurrent relay at South Harper 69 kv substation to open South Harper - Freeman 69 kv line upon reaching thermal limit of Freeman - Anaconda - Harrisonville West 69 kv line | \$20,000 | GMO | 06/01/10 | M | | 09/18/09 | | | |
| 20028 | 50078 | 30072 | regional reliability | Install (3) 7.2 Mvar capacitors for a total of 21.6 Mvar at Afon 69 kv bus. | \$800,000 | GRDA | 06/01/10 | M | | 01/27/09 | Afon 69 kv | | |
| 20001 | 10389 | 302 | zonal - sponsored | Tap the GRDA 1-Flint Creek 345 kv line and build a 345/161 transformer. Then build a 161 kv line down to Siloam Springs. | \$3,210,200 | GRDA | 06/01/10 | M | | | Siloam Springs Tap 161 kv | Siloam City 161 kv | 1 |
| 20001 | 10388 | 301 | regional reliability | Add second 161/69 kv 75 MVA autotransformer at Sallisaw | \$3,000,000 | GRDA | 06/01/10 | M | | 02/13/08 | Sallisaw 69 kv | Sallisaw 161 kv | 2 |
| 20009 | 50083 | 30077 | Zonal Reliability | New Craig 50 Mvar capacitor bank. | \$1,057,630 | KCPJL | 06/01/10 | M | | 02/13/08 | Craig 161 kv | | |
| | 10363 | 279 | zonal - sponsored | Replace Lenexa Circuit Switcher R1-4 with 2000 Amp Breaker | \$192,000 | KCPJL | 06/01/10 | M | | | Craig 161 kv | Lenexa 161 kv | 1 |
| | 10256 | 200 | zonal - sponsored | New Boulevard sub and new 161kv line | \$4,352,600 | KCPJL | 09/30/10 | M | | | Terrace 161 kv | Boulevard 161 kv | 1 |
| | 10257 | 201 | zonal - sponsored | New 161kv line | \$4,755,000 | KCPJL | 03/30/10 | M | | | Crosstown 161 kv | Boulevard 161 kv | 1 |
| | 10951 | 714 | regional reliability | Replace 200 A CT and 400 A wavetraps at Mayview to increase line rating. | \$5,000 | KCPJL | 06/01/10 | NTC | | | Amoco Pipeline 69 kv | Mayview Tap 69 kv | 1 |
| | 11144 | 866 | zonal - sponsored | Rebuild Sheldon to 20th & PIO. Upgrade based on condition of facility. | \$621,875 | LES | 05/31/10 | M | | | Sheldon 115 kv | 20th & PIO 115 kv | 1 |
| | 11145 | 867 | zonal - sponsored | Rebuild 3rd & Vandn to 20th & PIO. Upgrade based on condition of facility. | \$790,625 | LES | 05/31/10 | M | | | 3rd & Vandn 115 kv | 20th & PIO 115 kv | 1 |
| 20052 | 50223 | 30219 | transmission service | Rebuild approximately 14.5 miles of 34.5 kv line between Rice County and Ellinwood to achieve a minimum 600 amp emergency rating | \$1,812,500 | MIDW | 06/01/10 | M | | 09/18/09 | | | |
| 20054 | 50068 | 30062 | regional reliability | Add 138 kv 20 Mvar cap bank at Harper | \$1,400,000 | MIKEC | 06/01/10 | M | | 09/18/09 | Harper 138 kv | | |
| 20007 | 50087 | 30081 | regional reliability | Install (2) 12 Mvar capacitor banks at Pratt 115kv. | \$620,000 | MIKEC | 06/01/10 | M | | 02/13/08 | Pratt 115 kv | | |
| | 50202 | 30195 | zonal - sponsored | Add one 7.2 Mvar cap at Westminster | \$375,000 | NPPD | 06/01/10 | M | | | Westminster 34.5 kv | | |
| | 10981 | 744 | transmission service | Replace Canaday transformer. | \$5,000,000 | NPPD | 11/01/10 | M | | | Canaday 115 kv | Canaday 230 kv | 1 |
| | 10772 | 603 | regional reliability | Build 2.4 miles of new 115 kv line from Kansas/Nebraska state line to Steele City. | \$3,000,000 | NPPD | 10/01/10 | 06/01/10 | NTC | | Knob Hill 115 kv | Steele City 115 kv | 1 |
| | 10775 | 605 | regional reliability | | \$5,000,000 | NPPD | 06/01/10 | M | | | N. Platte 230 kv | N. Platte 115 kv | 2 |
| | 11160 | 606 | regional reliability | Build new 67 mile Columbus East - NW 68th & Holdrege 345 kv line. | | NPPD | 04/01/10 | M | | | Columbus East 345 kv | NW 68 and Holdrege 345 kv | 1 |
| | 11161 | 606 | regional reliability | Build new 12 mile Columbus East - Shell Creek 345 kv line. | | NPPD | 10/13/09 | M | | | Shell Creek 345 kv | Columbus East 345 kv | 1 |
| | 10970 | 606 | regional reliability | Upgrade Columbus East - Columbus line to 238 MVA. | | NPPD | 04/01/10 | M | | | Columbus East 115 kv | Columbus 115 kv | 1 |
| | 10971 | 606 | regional reliability | Upgrade Pawnee Lake - Seward line to 120 MVA. Portion of this line will be double circuited with the Columbus East - NW 68th & Holdrege 345 kv line project. | | NPPD | 04/01/10 | M | | | Pawnee Lk 115 kv | Seward 115 kv | 1 |
| | 10972 | 606 | regional reliability | Upgrade Pawnee Lake - NW 68th & Holdrege line to 137 MVA. Portion of this line will be double circuited with the Columbus East - NW 68th & Holdrege 345 kv line project. | \$150,000,000 | NPPD | 04/01/10 | M | | | Pawnee Lk 115 kv | NW 68th & Holdrege 115 kv | 1 |
| | 10973 | 606 | regional reliability | Upgrade Rising City - Seward line to 120 MVA. Portion of this line will be double circuited with the Columbus East - NW 68th & Holdrege 345 kv line project. | | NPPD | 04/01/10 | M | | | Rising City 115 kv | Seward 115 kv | 1 |
| | 11162 | 606 | regional reliability | Add Columbus East 345/115/13.8 kv transformer. | | NPPD | 10/13/09 | M | | | Columbus East 115 kv | Columbus East 345 kv | 1 |
| | 10957 | 720 | transmission service | Upgrade line to 240 MVA for WECC2. | \$6,750,000 | NPPD | 06/01/10 | M | | | Geneva 115 kv | Sutton 115 kv | 1 |
| | 10958 | 721 | transmission service | Upgrade line to 240 MVA for WECC2. | \$200,000 | NPPD | 06/01/10 | M | | | Hastings 115 kv | Hastings City 115 kv | 1 |

SPP Board of Directors Approved Appendix A projects January 26, 2010

Table with columns: ID, Line Number, Type, Description, Amount, Start Date, End Date, Status, Location, and Notes. The table lists various utility projects including transformer upgrades, line reconstructions, and substation work across different regions.

SPP Board of Directors Approved Appendix A projects January 26, 2010

| | | | | | | | | | | | | |
|-------|-------|---------------------------------|--|---|-------------|----------|----------|--------------|---------------------------|--|-----------------------------|---|
| 10877 | 671 | regional reliability | Increase CT ratio at both Chickasaw and Ardmore. Also possibly change out relay | \$450,000 | OGCE | 06/01/19 | | | Ardmore 69 kv | Chickasaw 69 kv | 1 | |
| 10999 | 30212 | regional reliability | Replace Jones Tap bus 1200A switch with 2000A switch. | \$250,000 | OGCE | 06/01/19 | | | Jones Tap 138 kv | Bryant 138 kv | 1 | |
| 11119 | 849 | regional reliability | Upgrade the existing 600 amp 69 kv switches in Kentucky Sub to 1200 amp | \$60,000 | OGCE | 06/01/19 | | | Kentucky 69 kv | Kentucky Tap 69 kv | 1 | |
| 11207 | 910 | regional reliability | Replace wavetrap | \$225,000 | OGCE | 06/01/19 | | | Bryant 138 kv | Memorial 138 kv | 1 | |
| 10906 | 859 | regional reliability | Replace South Waverly 161/69kv transformer with larger 30/33MVA model. interim mitigation is to move 20% of load off S Waverly 161kv bus starting in 2010. | \$2,000,000 | KCPL | 06/01/19 | | | South Waverly 161kv | South Waverly 69kv | 1 | |
| 11136 | 689 | regional reliability | Reconductor Hawthorn - Birmingham 161kv | \$1,670,625 | KCPL | 06/01/19 | | | Birmingham 161kv | Hawthorn 161kv | 1 | |
| 10994 | 30211 | regional reliability | Replace Medicine Lodge 138/115 kv transformer with a larger 147/170 MVA transformer | \$3,825,000 | MKEC | 06/01/19 | | | Medicine Lodge 138 kv | Medicine Lodge 115 kv | 1 | |
| 10991 | 30208 | regional reliability | Rebuild MKEC portion of the Clearwater-Milan tap 115 kv with bundled 1192.5 kcmil ACSR conductor (Bunting) | \$3,150,000 | MKEC | 06/01/19 | | | Clearwater 138 kv | Milan Tap 138 kv | 1 | |
| 10993 | 30210 | regional reliability | Replace Wave Trap at Harper Substation. | \$225,000 | MKEC | 06/01/19 | | | Harper 138 kv | Milan Tap 138 kv | 1 | |
| 10990 | 753 | regional reliability | Reconductor and upgrade terminal equipment to effect higher rating by 2019. 240 MVA Normal Continuous Rating. 240 MVA 4-Hour Emergency Rating. | \$6,000,000 | NPPD | 06/01/19 | | | Beatrice 115 kv | Harbine 115 kv | 1 | |
| 50254 | 30241 | regional reliability | Install 21.6 Mvar capacitor bank | \$2,213,000 | OPPD | 06/01/19 | | | Neb City LJ Sub 903 69 kv | | | |
| 50306 | 30269 | regional reliability | Install 2 Blocks of 14.4 Mvar | \$1,166,400 | SPS | 06/01/19 | | | Lamb Co 115 kv | | | |
| 50307 | 30270 | regional reliability | Install min. 2 blocks 14.4 Mvar | \$1,166,400 | SPS | 06/01/19 | | | Deaf Smith 115 kv | | | |
| 20031 | 10195 | 151 | regional reliability | Add third Tuco 115/69 kv autotransformer with 84/84 MVA rating. | \$1,280,000 | SPS | 06/01/19 | | Tuco 69 kv | Tuco 115 kv | 1 | |
| 20031 | 10197 | 153 | regional reliability | Add third Potash Junction Interchange 115/69 kv transformer. | \$600,000 | SPS | 06/01/19 | 01/27/09 | Potash Junc 69 kv | Potash Junc 115 kv | 1 | |
| 11092 | 825 | regional reliability | Reconductor 0.45 miles 69 kv from 4/0 to 397.5 ACSR | \$225,000 | SPS | 06/01/19 | | | Artesia 69 kv | CV-Artesia 69 kv | 1 | |
| 11094 | 827 | regional reliability | Reconductor 8.34 miles 115 kv from 397.5 to 750 ACSR | \$3,518,438 | SPS | 06/01/19 | | | Cherry 115 kv | Northwest 115 kv | 1 | |
| 11099 | 832 | regional reliability | Add 2nd transformer 115/69 kv 84/96 MVA CKT 2 | \$1,890,000 | SPS | 06/01/19 | | | Northwest 69 kv | Northwest 115 kv | 2 | |
| 11106 | 838 | regional reliability | Add new 115 kv Ckt Hockley Co-E Levelland Co | \$3,037,500 | SPS | 06/01/19 | | | Hockley Co 115 kv | E Levelland 115 kv | 1 | |
| 11128 | 855 | regional reliability | convert 69 kv load onto 115 kv | 85375 | SPS | 06/01/19 | | | Stanton 69 kv | Stanton 69 kv | 1 | |
| 11198 | 901 | regional reliability | Replace NICHOLS Line Trap with 1200 Amp B unit 230 kv | \$450,000 | SPS | 06/01/19 | | | Nichols Station 230 kv | Amarillo South Interchange 230 kv | 1 | |
| 10860 | 655 | regional reliability - non OATT | Replace Springfield transformer #1 three winding transformer with 70 MVA auto transformer. | \$825,000 | SWPA | 06/01/19 | | | Springfield 161 kv | Springfield 69 kv | 1 | |
| 11193 | 898 | zonal - sponsored | convert County Line - Arnold to 115 kv. Valley Falls sub converted to 115 | \$9,521,875 | WR | 06/01/19 | M | | County Line 115 kv | Valley Falls 115 kv | 1 | |
| 11194 | 898 | zonal - sponsored | convert County Line - Arnold to 115 kv. Valley Falls sub converted to 115 | \$9,534,375 | WR | 06/01/19 | M | | Arnold 115 kv | Valley Falls 115 kv | 1 | |
| 10992 | 30209 | regional reliability | Rebuild Westar portion of the Clearwater-Milan tap 115 kv with bundled 1192.5 kcmil ACSR conductor (Bunting) | \$3,431,250 | WR | 06/01/19 | | | Clearwater 138 kv | Milan Tap 138 kv | 1 | |
| 20000 | 10444 | 347 | Reconductor with 2.7 miles 477 ACSR 69 kv Woodlawn-Baldwin. Reset relays. | \$2,000,000 | AEP | 06/01/11 | D | NTC-Withdraw | 02/13/08 | Baldwin 69 kv | Woodlawn 69 kv | 1 |
| 20027 | 10614 | 477 | Reconductor 6.9 miles with 477 ACSR 69 kv from Baldwin - Karnack Tap. | \$6,900,000 | AEP | 06/01/13 | D | NTC-Withdraw | 01/27/09 | Baldwin 69 kv | Karnack Tap 69 kv | 1 |
| 20016 | 10442 | 345 | Replace 69 kv switch at Magnolia tap for new emergency limit 85 MVA. | \$125,000 | AEP | 06/01/10 | D | NTC-Withdraw | 01/16/09 | Quitman-Magnolia 69 kv | Forest Hills REC 69 kv | 1 |
| 20011 | 10572 | 441 | Reconductor 69kv line from 636 ACSR to 782.8 ACSS/TW | \$805,000 | CUS | 06/01/12 | D | NTC-Withdraw | 02/13/08 | Kickapoo 69 kv | Sunset 69 kv | 1 |
| 20034 | 50182 | 30174 | Install 5 Mvar capacitor at Craig 69 kv bus. | \$350,000 | GMO | | D | NTC-Withdraw | 01/27/09 | Craig 69 kv | | |
| 20034 | 50082 | 30076 | Install 12 Mvar capacitor at Warsaw 69 kv bus. | \$409,900 | GMO | | D | NTC-Withdraw | 01/27/09 | Warsaw 69 kv | | |
| 20028 | 50185 | 30177 | Add additional 7.2 Mvar capacitor at Tahlequah West. for a 28.8 Mvar total. | \$291,600 | GRDA | | D | NTC-Withdraw | 1/27/2009 | Tahlequah West 69 kv | | |
| 20009 | 10492 | 379 | New Hillsdale-Cedar Niles 161 kv Line and Cedar Niles ring bus | \$5,418,700 | KCPL | 06/01/15 | D | NTC-Withdraw | 02/13/08 | Hillsdale 161 kv | Cedar Niles 161 kv | 1 |
| 20002 | 10515 | 397 | Convert 7 mile Mustang -Yukon 69 kv line to 138 kv. | \$6,850,000 | OGCE | 06/01/12 | D | NTC-Withdraw | 02/13/08 | Mustang 138 kv | Yukon 138 kv | 1 |
| 20002 | 10516 | 397 | Convert 3 mile Yukon - Cimarron 69 kv line to 138 kv. | \$3,500,000 | OGCE | 06/01/12 | D | NTC-Withdraw | 02/13/08 | Yukon 138 kv | Cimarron 138 kv | 1 |
| 20003 | 50100 | 30094 | Install 6 Mvar capacitor at Mustang 69 kv. | \$168,000 | WFEC | | D | NTC-Withdraw | 02/13/08 | Mustang 69 kv | | |
| 20033 | 10811 | 623 | Rebuild the 14.63 miles of 69 kv line from Timber Junction - Winfield. | \$7,415,000 | WR | 12/31/10 | D | NTC-Withdraw | 01/27/09 | Timber Junction 69 kv | City Of Winfield 69 kv | 1 |
| 20033 | 10812 | 624 | Build new 8.76 mile Fort Junction - West Junction City 115 kv line that follows the path of the JEC - Summit 345 kv line. Remove old double circuit and West Junction City Junction (East) - West Junction City 115 kv line. | \$4,927,500 | WR | 06/01/11 | D | NTC-Withdraw | 01/27/09 | Fort Junction Switching Station 115 kv | West Junction City 115 kv | 1 |
| 20006 | 10536 | 410 | Rebuild Ark Valley-Tower 33 115 kv | \$2,306,250 | WR | | D | NTC-Withdraw | 02/13/08 | Ark Valley 115 kv | Tower 33 115 kv | 1 |
| 20033 | 10640 | 485 | Rebuild the 5.49 mile Lawrence Hill to Mockingbird Hill 115 kv line. | \$2,377,448 | WR | | D | NTC-Withdraw | 01/27/09 | Lawrence Hill 115kv | Mockingbird Hill 115 kv | 1 |
| 20033 | 10218 | 169 | Uprate CT ratio on Chapman - Clay Center 115 kv line. | \$10,000 | WR | 06/01/17 | D | NTC-Withdraw | 01/27/09 | Chapman 115 kv | Clay Center Junction 115 kv | 1 |