



**Southwest Power Pool**  
**TRANSMISSION WORKING GROUP MEETING**  
**August 26, 2010**  
**Teleconference**

• M I N U T E S •

**Agenda Item 1 – Administrative Items**

TWG Chair Noman Williams called the meeting to order at 9:00 a.m. The following people were in attendance: (Attachment 1 – Proxies)

TWG Members

Noman Williams, Sunflower Electric Power Corp  
Jason Atwood, Dogwood Energy  
Wiktor Charytoniuk for Angela Easton, Calpine Energy Services  
Jason Fortik, Lincoln Electric System  
Ronnie Frizzell, Arkansas Electric Cooperative  
Bruce Cude for John Fulton, Southwestern Public Services  
Mark Hamilton for Travis Hyde, Oklahoma Gas and Electric  
Dan Lenihan, Omaha Public Power District  
Randy Lindstrom, Nebraska Public Power District  
Jim McAvoy, Oklahoma Municipal Power Authority  
Sam McGarrah, Empire District Electric  
Nathan McNeil, Midwest Energy  
Matt McGee, American Electric Power  
Jason Shook, GDS Associates for ETEC  
Don Taylor, Westar Energy  
Harold Wyble, Kansas City Power & Light

Other Stakeholders and Staff

Syed Ahmad, FERC Staff  
Dustin Betz, Nebraska Public Power District  
Brian Brownlow, Nebraska Public Power District  
Charles Cates, SPP Staff  
Tony Gott, Associated Electric Cooperative  
Brett Hooton, SPP Staff  
Rachel Hulett, SPP Staff  
Tim McGinnis, SPP Staff  
Ben Roubique, SPP Staff  
Al Tamimi, Sunflower Electric Power Corp  
Keith Tynes, SPP Staff

**Agenda Item 2 – ITP 20 - Economic Constraints**

Ben Roubique, SPP Staff, explained the ITP 20-Year Assessment constraint analysis. On top of the N-1 assessment of the system to determine constraints, staff also reanalyzed several existing flowgates to determine if transmission upgrades relieved congestion. The results are available on TrueShare and are split into three tabs: a summary, all constraints, and an N-1 assessment done after identifying the constraints in second tab. The overall constraints, shown in the second tab, list all constraints with ratings SPP will use. After identifying all constraints SPP performed an additional N-1 analysis to determine if



the constraints limited congestion, which is represented in the third tab. The group discussed the results, and several people commented that the constraints had incorrect ratings. Staff recognized the ratings for many constraints were incorrect, and staff will correct and repost them. In the discussion, other comments were given, and staff will address them in the constraint updates.

Staff stated these identified constraints were necessary for the business as usual future scenario, noting the other futures could potentially need additional constraints.

Comments on the constraints were due by end of business Friday, August 27. Staff will post the updated constraints by August 31. TWG will be able to provide comments on the updated constraints.

### **Agenda Item 3 – ITP Manual**

The group reviewed and revised a portion of the ITP manual (Attachment 2 – ITP Manual). With no time remaining on the call, the group tabled discussion of this item to the next TWG meeting.

### **Agenda Item 4 – Adjournment**

Rachel reminded everyone of the future joint meetings with the ESWG: August 31 (web conference), September 13 (web conference), and October 4 (face-to-face). To continue work on the ITP manual, the group scheduled a web conference for September 1, 1-3 p.m.

With no further business, Noman Williams adjourned the meeting at 11:20 a.m.

Respectfully Submitted,

Rachel Hulett  
TWG Secretary

## OGE, Mark Hamilton for Travis Hyde

---

**From:** Hyde, Travis D [mailto:hydtd@oge.com]  
**Sent:** Wednesday, August 18, 2010 8:44 AM  
**To:** Rachel Hulett  
**Cc:** Hamilton, Mark  
**Subject:** RE: TWG 8/26/10 Teleconference Registration

Rachel,  
I can't attend the TWG call next week. Mark Hamilton has my proxy for the meeting.

Thanks,

Travis D. Hyde, PE  
Manager  
OG&E Transmission Planning  
405-553-5969 (office)  
405-219-2634 (cell)  
[hydtd@oge.com](mailto:hydtd@oge.com)

## Calpine, Wiktor Charytoniuk for Angela Easton

---

**From:** Angela Easton [mailto:Angela.Easton@calpine.com]  
**Sent:** Thursday, August 19, 2010 8:57 AM  
**To:** Rachel Hulett  
**Cc:** Wiktor Charytoniuk  
**Subject:** Proxy for the Transmission Working Group Teleconference on 8/26

Hi Rachel,

For the Transmission Working Group Teleconference on 8/26, I would like for Wiktor Charytoniuk to be my proxy.

Regards,

Angela

---

**Angela Easton**  
Transmission Analyst

Calpine  
717 Texas Ave. Suite 1000  
Houston, TX 77002

713.570.4606 (office)  
713.830.8722 (fax)  
[eastona@calpine.com](mailto:eastona@calpine.com)

## SPS, Bruce Cude for John Fulton

---

**From:** Fulton, John S [mailto:John.Fulton@XCELENERGY.COM]  
**Sent:** Thursday, August 26, 2010 8:59 AM  
**To:** Williams, Noman; Hyde, Travis  
**Cc:** Rachel Hulett; Cude, Bruce  
**Subject:** TWG CALL on 8-26-2010 - proxy

Due to poor scheduling on my part, I won't be able to make the call. Bruce Cude will have my proxy to vote on any issues for SPS.

**John S. Fulton**

**Xcel Energy | Responsible By Nature**

**Manager, Transmission Asset Management**

600 South Tyler, 21 Amarillo, TX 79101

**P:** 806.378.2193 **C:** 806.679.0801 **F:** 806.378.2190

**E:** [John.Fulton@xcelenergy.com](mailto:John.Fulton@xcelenergy.com)

---

**XCELENERGY.COM**

Please consider the environment before printing this email.



# Draft

## Integrated Transmission Planning Manual

MAINTAINED BY  
Planning

PUBLISHED: [Click [here](#) and type **MM/DD/YYYY**]  
LATEST REVISION: 08/27/2010

*you can move or resize this text box by clicking on the edge and dragging*

*Copyright © YEAR by Southwest Power Pool, Inc. All rights reserved.*



## Table of Contents

1		
2		
3		
4	<b>Draft</b> .....	<b>i</b>
5	<b>Integrated Transmission Planning Manual</b> .....	<b>i</b>
6	<b>I. Introduction</b> .....	<b>3</b>
7	A. Acronyms and Definitions .....	3
8	B. Purpose .....	4
9	C. ITP Overview.....	4
10	D. Background.....	5
11	<b>II. Transmission Planning Upgrade Process</b> .....	<b>6</b>
12	A. ITP Process & Schedule .....	6
13	B. Cost-Effective Analysis & Robustness Evaluation .....	7
14	1. Development of Assumptions .....	8
15	C. Recommendations and Results .....	8
16	<b>III. Twenty-Year Integrated Transmission Planning</b> .....	<b>9</b>
17	A. Purpose.....	9
18	B. Futures Evaluation .....	9
19	C. Data Requirements & Assumptions .....	9
20	1. Confidentiality of Data .....	9
21	2. Modeling Footprint .....	9
22	3. Generating Unit Modeling Data .....	10
23	4. Wind Resources .....	10
24	5. Load Forecast Assumptions .....	10
25	6. Fuel and Emission Prices .....	10
26	7. Import/Export Limits.....	10
27	D. Modeling Methods.....	11
28	1. Model Development .....	11
29	2. Security-Constrained Economic Dispatch .....	11
30	3. Power System Model for the economic dispatch model.....	11
31	4. Resource Planning Data.....	12
32	5. Constraint Selection.....	12
33	E. Twenty-Year ITP Assessment Process .....	12
34	1. Resource Planning .....	12
35	2. Screening Analysis .....	12
36	3. Security Constrained Unit Commitment and Economic Dispatch Analysis.....	12
37	4. Limited Reliability Assessment .....	13
38	5. Solution Development.....	13
39	F. Valuation .....	14
40	1. Cost-Effective: Individual Futures.....	14
41	2. Flexibility: Meeting Multiple Futures .....	15
42	3. Robustness Metrics (will be updated as ESWG reviews the CRA results) .....	16
43	G. Deliverable .....	19
44	1. Finalize Solution .....	19
45	2. Report .....	19
46	<b>IV. Ten-Year Integrated Transmission Planning</b> .....	<b>19</b>
47	A. Purpose.....	19
48	B. Futures Evaluation .....	19
49	C. Data Requirements .....	19
50	1. Confidentiality of Data.....	19
51	2. Generating Unit Modeling Data .....	20
52	3. Reliability/Must-Run Conditions.....	20



53	4.	Wind Farms.....	20
54	5.	Interaction with ERCOT & WECC .....	20
55	6.	Stakeholder Review of Modeling Assumptions .....	20
56	D.	Assumptions.....	20
57	1.	Load Forecast Assumptions .....	20
58	2.	Fuel Prices .....	20
59	3.	Emission Prices .....	20
60	4.	Modeling Footprint .....	20
61	5.	Import/Export Limits .....	20
62	E.	Modeling Methods.....	20
63	1.	Power Flow/Security-Constrained Economic Dispatch .....	20
64	2.	Flowgate Definition .....	21
65	F.	Ten-Year ITP Process.....	21
66	1.	Model Development.....	21
67	2.	Flowgate Selection .....	21
68	3.	Screening Analysis .....	21
69	4.	Additional Flowgate Analysis.....	21
70	5.	Security Constrained Unit Commitment and Economic Dispatch Analysis.....	21
71	6.	PSS@E MUST Commercial Path Analysis .....	21
72	7.	Transfer Capability Analysis .....	21
73	8.	Solution Development.....	21
74	G.	Calculation of Benefits .....	21
75	1.	Cost-Effective Planning .....	21
76	H.	Deliverable .....	21
77	1.	Finalize Solution .....	22
78	<b>V.</b>	<b>Near-Term Integrated Transmission Planning .....</b>	<b>22</b>
79	A.	Purpose.....	22
80	B.	20-Year and 10-Year ITP Interaction.....	22
81	C.	Data Requirements .....	22
82	1.	Confidentiality of Data.....	23
83	D.	Assumptions.....	23
84	1.	MDWG Modeling .....	23
85	E.	Near-Term ITP Process .....	24
86	1.	Model Development Process.....	25
87	2.	Inter-Regional Coordination.....	29
88	3.	Transmission Operating Guides .....	29
89	4.	Assessment Methodology.....	29
90	5.	Solution Development.....	29
91	F.	Deliverable .....	29
92	1.	Finalize Solution .....	30
93	<b>VI.</b>	<b>Issuance of NTCs and ATPs.....</b>	<b>30</b>
94	<b>VII.</b>	<b>Reporting Requirements .....</b>	<b>30</b>
95	A.	Stakeholder Review Process .....	30
96	<b>VIII.</b>	<b>Ongoing Economic Modeling &amp; Methods Process.....</b>	<b>30</b>
97	A.	Interaction with Other SPP Data & Modeling Activities.....	30
98		<b>Appendix A .....</b>	<b>32</b>
99		<b>Appendix B .....</b>	<b>33</b>
100			
101			
102			

103 **I. Introduction**

104  
105 **A. Acronyms and Definitions**

Comment [rah1]: Add ERCOT and WECC

- 107 1. AECl – Associated Electric Cooperative, Inc.
- 108 2. APC – Adjusted Production Cost: APC is a dollar value calculated by adding the cost of
- 109 producing energy to the cost of energy purchases and subtracting the revenue from
- 110 energy sales
- 111 3. ATP – Authorization to Plan: The ATP is a status given to a project which indicates that
- 112 the BOD has approved the project in the SPP ITP and it has not yet been issued an NTC
- 113 because it is outside of the NTC financial commitment window.
- 114 4. BOD – SPP Board of Directors/Members Committee: The BOD is the governing body of
- 115 SPP
- 116 5. EHV – Extra High Voltage: In this document EHV refers to transmission at 345kV or
- 117 greater
- 118 6. ESWG – Economic Studies Working Group: The ESWG reports to the MOPC and
- 119 advises and assists SPP staff, various working groups and task forces in the
- 120 development and evaluation principles for economic studies
- 121 7. FERC – Federal Energy Regulatory Commission
- 122 8. ITP – Integrated Transmission Plan: The ITP is SPP’s approach to planning
- 123 transmission needed to maintain reliability, provide economic benefits, and achieve
- 124 public policy goals to the SPP region in both the near and long-term
- 125 9. LMP – Locational Marginal Price: Also known as nodal pricing, the LMP is the
- 126 incremental cost to the system that would result from one additional unit of energy that is
- 127 demanded at a particular node
- 128 10. MAPP – Mid-Continent Area Power Pool
- 129 11. MDWG – Model Development Working Group: The MDWG is responsible for
- 130 maintenance of an annual series of transmission planning models (powerflow and short
- 131 circuit models and associated stability database) which represent the current and
- 132 planned electric network of SPP
- 133 12. MISO – Midwest Independent System Operator
- 134 13. MOPC – Markets and Operations Policy Committee:
- 135 14. MTF – Metrics Task Force: The MTF is a task force created by the ESWG to create a
- 136 list of metrics for the ESWG to consider for use in evaluating projects in the ITP
- 137 15. NERC – North American Electric Reliability Corporation
- 138 16. NERC TPL – NERC Transmission Planning Standards
- 139 17. NTC – Notification to Construct: The NTC is a formal SPP document specifying
- 140 approval of and notification to build specific network upgrades with specified need dates
- 141 for commercial operation
- 142 18. OATT – Open Access Transmission Tariff: SPP’s transmission tariff as posted on SPP’s
- 143 website
- 144 19. PJM – PJM Interconnection
- 145 20. PTDF – Power Transfer Distribution Factor: A PTDF is the amount of power that will flow
- 146 given a particular source and sink based on the impedance of the system
- 147 21. ROW – Right-of-Way: The ROW identifies the strip of land which is needed for
- 148 transmission purposes
- 149 22. RSC – Regional State Committee: The SPP RSC provides collective state regulatory
- 150 agency input on matters of regional importance related to the development and
- 151 operation of bulk electric transmission
- 152 23. SERC – SERC Reliability Corporation
- 153 24. SPP – Southwest Power Pool, Inc.: SPP is a Regional Transmission Organization

Comment [rah2]: Doesn’t match Criteria 4 or Tariff defs



- 154 25. SPPT – Synergistic Planning Project Team (SPPT): The SPPT is a team which was
- 155 created to address comprehensive transmission planning processes and allocation of
- 156 transmission costs associated with both existing and strategic issues including
- 157 transmission service, generator interconnection, Extra High Voltage (EHV) inter-regional
- 158 transmission, wind integration, etc
- 159 26. STEP – SPP Transmission Expansion Plan: The STEP is an annual plan which
- 160 summarizes activities that impact future development of the SPP transmission grid
- 161 27. TLR – Transmission Loading Relief: A TLR is a process which is used to reduce loading
- 162 on lines which are at risk for an overload
- 163 28. TWG – Transmission Working Group: The TWG reports to the MOPC and is
- 164 responsible for planning criteria to evaluate transmission additions, seasonal ATC
- 165 calculations, seasonal flowgate ratings, oversight of coordinated planning efforts, and
- 166 oversight of transmission contingency evaluations
- 167

168 **B. Purpose**

169 The SPP Tariff (OATT) in Attachment O Section III.8.d requires that Southwest Power Pool, Inc.

170 (SPP) assess the cost effectiveness of proposed transmission projects in accordance with the

171 Integrated Transmission Planning Manual. This manual will outline the processes for the three

172 Integrated Transmission Planning components: 20-Year, 10-Year, and Near-Term

173 Assessments.

174

175

176 **C. ITP Overview**

177

178 The Integrated Transmission Plan (ITP) is SPP's approach to planning transmission needed to

179 maintain reliability, provide economic benefits and achieve public policy goals to the SPP region

180 in both the near and long-term. The ITP enables SPP and its stakeholders to facilitate the

181 development of a robust transmission grid that provides regional customers improved access to

182 the SPP region's diverse resources. Development of the ITP was driven by planning principles

183 developed by the Synergistic Planning Project Team (SPPT), including the need to develop a

184 transmission backbone large enough in both scale and geography to provide flexibility to meet

185 SPP's future needs.

186

Deleted: and the planning principles it developed

187 The ITP is an iterative three-year process that includes 20-Year<sup>1</sup>, 10-Year, and Near-Term

188 Assessments and targets a reasonable balance between long-term transmission investment

189 and customer congestion costs (as well as many other benefits).

190

191 The ITP creates synergies by integrating existing SPP activities: the Extra High Voltage (EHV)

192 Overlay, the Balanced Portfolio, and the SPP Transmission Expansion Plan (STEP) Reliability

193 Assessment. Consequently, and reaching the balance above, efficiencies are expected to be

194 realized in the Generation Interconnection and Aggregate Transmission Service Request study

195 processes. The ITP works in concert with SPP's existing sub-regional planning stakeholder

196 process, and parallels the NERC TPL Reliability Standards compliance process.

197

198 The Economic Studies Working Group (ESWG) was also formed in conjunction with the

199 development of the ITP and will maintain the processes and metrics on an ongoing basis for

200 qualifying and quantifying the transmission projects for the 20-Year and 10-Year Assessments.

201

---

<sup>1</sup> The first iteration of the 20-Year Assessment is studying only year 20. However, in the future ITPs multiple years may be studied in addition to the year 20.

204 The Transmission Working Group (TWG) will maintain the process on an ongoing basis for  
 205 qualifying and quantifying the transmission projects for the Near-Term Assessment.

206 ITP recommendations that are reviewed by the Market Operations and Policy Committee  
 207 (MOPC) and approved by the Board of Directors (BOD) will allow staff to issue Notification to  
 208 Construct (NTC) letters for approved projects needed within the financial commitment horizon.  
 209 An Authorization to Plan (ATP) will be issued for projects needed beyond the financial horizon.  
 210 Once an ATP is issued, the project will be reviewed annually to ensure the continued need for  
 211 the project and the proper timing.

Deleted: NTC or

Comment [TLM3]: We should address separately because NTC changes might raise issues in some minds? Although this is ok in reality per Alan, others.....Even NTCs get reviewed... We're ok.

212 Successful implementation of the ITP will result in a list of transmission expansion projects,  
 213 projected project costs and completion dates that facilitate the creation of a cost-effective,  
 214 robust, and responsive transmission network in the SPP footprint.

Deleted: required in-service date.

218 **D. Background**

219 In January of 2009 the BOD created the SPPT to address gaps and conflicts in SPP's  
 220 transmission planning processes; to develop a holistic, proactive approach to planning that  
 221 optimizes individual processes; and to position SPP to respond to national energy priorities.

222 The SPPT recommended the organization adopt a new set of planning principles; develop and  
 223 implement an ITP; develop a plan to monitor the construction of projects approved through the  
 224 ITP process; and identify Priority Projects that continue to appear in system reviews as needed  
 225 to relieve congestion on existing constraints and connect SPP's eastern and western regions.  
 226 The SPPT recommended that the Regional State Committee (RSC) establish a "highway-  
 227 byway" cost allocation methodology for approved projects.<sup>2</sup>

228 The SPPT created the following principles to drive development of the ITP:

- 229 • Focus on regional needs, while considering local needs as well; long range plans (both  
 230 20-year and 10-year) are to be updated every three years while near-term plans are to  
 231 be updated annually.
- 232 • Plan the backbone transmission system to serve SPP load with SPP resources in a cost-  
 233 effective manner. The transmission backbone will:
  - 234 o Enhance interconnections between SPP's western and eastern regions
  - 235 o Strengthen existing ties to the Eastern Interconnection.
  - 236 o Provide options for planning and coordination to the Western Electricity  
 237 Coordinating Council and the Electric Reliability Council of Texas grids in the  
 238 future.
- 239 • Incorporate 20-year physical modeling and 40-year financial analysis timeframe.
- 240 • Better position SPP to proactively prepare for and respond to national priorities while  
 241 providing flexibility to adjust expansion plans.

242 SPP began performing its planning duties in accordance with the ITP process in January of  
 243 2010, shortening the 20-year Assessment from an 18 month process to a 12 month process.

<sup>2</sup> The Highway-Byway cost allocation was approved by FERC on June 17, 2010.  
<http://elibrary.ferc.gov/idmws/nvcommon/NVintf.asp?slcfilelist=12369183:0>


252 **II. Transmission Planning Upgrade Process**

253 **A. ITP Process & Schedule**

254 Beginning in November 2009, SPP began working with stakeholders to develop the scenarios  
 257 for the 20-Year Assessment with results to be presented in January 2011.<sup>3</sup> The 10-Year and  
 258 Near-Term Assessments will be performed in 2011, with results presented in January 2012.  
 259


**S = Scenarios & Modeling**  
**A = Analysis**  
**R = Results**

**ITP Schedule  
 (Transition Cycle)**



260  
 261  
 262  
 263 Moving forward, evaluation of future scenarios that may affect the ITP will occur during the first  
 264 half of 2012 for the 20-Year Assessment and during the second half of 2013 for the 10-Year  
 265 Assessment. The 20-Year Assessment will begin in year one and be completed in year two. The  
 266 10-Year Assessment will begin during year two and be completed in year three. The Near-Term  
 267 Assessment will be performed each year to ensure reliability and to incorporate local planning  
 268 requirements.  
 269

<sup>3</sup> ITP Final Process Document - [http://www.spp.org/publications/ITP\\_Process\\_Final\\_20091029.pdf](http://www.spp.org/publications/ITP_Process_Final_20091029.pdf)



270  
271  
272  
273  
274  
275  
276  
277  
278  
279  
280  
281  
282  
283  
284

The ITP process is an iterative three-year component of the STEP that includes 20-Year, 10-Year, and Near-Term Assessments. Each of these assessments targets a reasonable balance between long-term transmission investment and customer congestion costs. Investment in transmission lowers the congestion costs (among many other benefits) to which customers are exposed but this benefit must be weighed against the cost of the investment. As each assessment concludes more clarity is provided concerning appropriate investments in new transmission. Finding the appropriate investments is dependent on the assumptions used to represent possible future outcomes. This targeted approach is both forward-looking and proactive by designing with an end in mind of having a cost-effective and responsive transmission network which adheres to the ITP principles and also keeps the FERC “Nine Transmission Principles” in the forefront.<sup>4</sup>

**B. Cost-Effective Analysis & Robustness Evaluation**

285  
286  
287  
288  
289  
290  
291  
292

Analysis will be performed following the adoption of the study assumptions and will focus upon both cost-effectiveness and robustness.

Cost-effective analysis is a form of economic analysis that compares the relative costs and outcomes (effects) of two or more courses of action. In effect, the benefits side of the equation is held constant at some pre-determined standard of service, and various options for providing

<sup>4</sup> These FERC principles are coordination, openness, transparency, information exchange, comparability, dispute resolution, regional participation, economic planning (congestion) studies, and cost allocation for new projects, as described more fully in Order 890, Final Rule, pages 245 – 323.

293 that standard of service are then compared, with the least-cost method identified as the  
294 preferred option. This method is distinct from cost-benefit analysis, which assigns a monetary  
295 value to the measure of effect with the most balanced outcome of costs and effects is identified.  
296 Cost-effective and cost-benefit analyses ask two different questions, “is the equation balanced”  
297 and “How can I achieve my goals in the most effective manner?”  
298

299 An evaluation of robustness involves a different perspective than does the cost  
300 effectiveness analysis. Robustness includes an evaluation of changes to cost-effective  
301 transmission plans for flexibility as well as increment cost and benefits. Metrics of  
302 robustness may be quantitative and/or qualitative.

### 303 **1. Development of Assumptions**

304  
305 Assumptions used in the ITP will be developed during the first and second year of each  
306 three-year ITP cycle for the 20-Year and 10-Year Assessments, respectively, and  
307 annually for the Near-Term Assessment. Assumptions will include those needed for  
308 economic studies, reliability studies, and futures development.  
309

310 The ESWG will guide the development of the assumptions used in the economic  
311 assessments and the TWG will guide the development of the assumptions for the  
312 reliability impact assessments.  
313

314 Once developed, staff will present the assumptions within an ITP study scope document  
315 for approval by the ESWG, TWG, and MOPC (with review from the RSC) as appropriate.  
316 The scope of each assessment will be revisited at the beginning of each three-year  
317 cycle of the ITP.  
318

319 In addition to any assumptions identified by the ESWG and TWG, the analysis must  
320 also encompass a plausible collection of assumptions for each specific model run  
321 including, but not limited to, varying levels of the following:

- 322 • Renewable Electricity Standards
  - 323 • Load growth
  - 324 • Demand response
  - 325 • Energy efficiency
  - 326 • Fuel prices
  - 327 • Environmental and governmental regulations
  - 328 • Resource (e.g. generation, transmission, smart grid) Technology
  - 329 • Public Policy
- 330  
331

### 332 **C. Recommendations and Results**

333 A list of projects from the assessments performed throughout the year will be presented to  
334 stakeholders for discussion and review at an SPP planning summit. Staff will then make any  
335 necessary adjustments to the ITP based on stakeholder feedback. The final plan will be  
336 included as a component of the STEP report and presented to the MOPC and the BOD.  
337  
338

339 **III. Twenty-Year Integrated Transmission Planning**

340  
341 **A. Purpose**

342  
343 | The first phase of the ITP process is the 20-Year Assessment<sup>1</sup> which will be used to develop an  
344 EHV backbone network. The value-based planning assessment will use a diverse array of  
345 power system and economic analysis tools to thoroughly study the transmission system to  
346 identify cost-effective and robust backbone projects needed to provide a grid flexible enough to  
347 reasonably accommodate possible changes characterized by the various scenarios. Because  
348 the degree to which the power transmission landscape will change over this time frame is not  
349 currently known, transmission system expansion will be designed with flexibility (i.e., enables  
350 the ability of the transmission grid to meet a range of possible resource futures) in mind. The  
351 projects identified as a result of the 20-Year Assessment will be expected to provide benefits to  
352 the region across multiple scenarios.

Deleted: <sup>5</sup>

353  
354  
355 **B. Futures Evaluation**

356  
357 Due to the uncertainties involved in forecasting future system conditions, a number of diverse  
358 futures or scenarios will be considered that take into account multiple variables. Consideration  
359 of multiple futures or scenarios will provide for a transmission expansion plan that will evolve as  
360 economic, environmental, regulatory, public policy, and technological changes arise that affect  
361 the industry. Initiatives such as plug-in hybrid electric vehicles, smart grid, renewable electricity  
362 standards, environmental regulations, energy storage and conversion applications, and other  
363 future technologies will change the way the electric grid is utilized. The futures are defined by  
364 the SPP Strategic Planning Committee (SPC). Based on direction of the SPC, the ESWG  
365 would further develop the assumptions and the inputs for the futures.

366  
367  
368 **C. Data Requirements & Assumptions**

369  
370 Each stakeholder will have the opportunity to submit data and review their individual data which  
371 is being used for the study. The original data set to be used in the model will be provided by the  
372 vendor retained by SPP. That data is then reviewed by the stakeholders who can then provide  
373 specific updates to non-sensitive data. Data pertaining to unit costs and heat rate will not be  
374 updated by stakeholders. The ESWG will coordinate the submitting and vetting of all data used  
375 in the economic analysis. This data includes generating unit information, load, wind profiles,  
376 emission prices, fuel prices, etc.

377 **1. Confidentiality of Data**

378  
379 In addition to the treatment with respect to reporting requirements in Section 2.6, in all other  
380 activities SPP staff will take all reasonable efforts to preserve the confidentiality of information in  
381 accordance with the provisions of the OATT (i.e., Sections 17.2(iv) and 18.2(vii); Attachment V  
382 (Section 13.1 and Article 22 of Appendix 6); Exhibit 1 (Section 2.3); Attachment AJ (Section 8);  
383 and Attachment C-One (Clause 7)).

384 **2. Modeling Footprint**

385

387 The modeling footprint will include the entire SPP region and nearby areas within the Eastern  
 388 Interconnection. The non-SPP areas that may be modeled are MAPP, Midwest ISO, and the  
 389 western portions of PJM and SERC.

Comment [rah4]: Explain T1 and T2 stuff

390 **3. Generating Unit Modeling Data**

391  
 392 Generating unit modeling data is required to perform a detailed analysis of economic upgrades.  
 393 Stakeholders are asked to review the data inputs for their generating units. Specific data types  
 394 will be derived from publically available inputs provided by the vendors. These data types  
 395 include: Variable O&M, Variable O&M Escalation, Fixed O&M, Fixed O&M Escalation, Energy  
 396 Bid Cost, Energy Bid Markup, Spinning Reserve Bid, Spinning Reserve Bid Escalation, Heat  
 397 Rate, Startup Cost Adder, and Startup Cost Adder Escalation. These specific inputs use  
 398 publically available data to ensure that the model will not contain sensitive data.

399  
 400 Stakeholders will be asked to review and provide updated values (if necessary) for certain data  
 401 items. These data types include but are not limited to: Maximum MW Output, Minimum MW  
 402 Output, Must-Run status, Minimum Up Time, Minimum Down Time, Ramp Rate, Forced Outage  
 403 Rate, Forced Outage Duration, Maintenance Hours Requirement, Minimum Runtime, Startup  
 404 Energy Requirement, Fuel Type, and Emission Rates. For the resource planning phase of this  
 405 study, stakeholders will be asked to review and update a smaller set of input data.  
 406

407 **4. Wind Resources**

408  
 409 Futures may require the modeling of additional wind capacity above what is currently in service  
 410 at the time of the assessment. The amount of wind which will be modeled is defined in the ITP  
 411 Futures document which is proposed by the ESWG and approved by the appropriate governing  
 412 committee. The target wind level is then met by including additional wind sites in the modeling  
 413 footprint. The size and locations of these additional wind farms are approved by the ESWG.

Deleted:

414 **5. Load Forecast Assumptions**

415  
 416 A base load forecast used for the 20-Year Assessment will be approved by the Model  
 417 Development Working Group (MDWG) and reviewed by the TWG and ESWG. Sensitivities may  
 418 be developed for the futures.  
 419

420 **6. Fuel and Emission Prices**

421  
 422 SPP staff will assist the ESWG to formulate the fuel and emission price forecasts. These  
 423 forecasts will then be approved by the ESWG for use in the production cost model.  
 424

425 **7. Import/Export Limits**

426  
 427 The ITP will focus on benefits to the SPP region. The interchange between SPP and other  
 428 regions be kept to a minimum percentage of SPP's total load and capacity. The imports and  
 429 exports will be set and benchmarked using hurdle rates and expected external system  
 430 conditions for twenty years in the future. The ESWG will review the hurdle rates and the  
 431 resulting imports/exports for both the resource planning and production cost modeling phases of  
 432 the study. Different hurdle rates may be used to accommodate import and export scenarios



434 within the futures depending on the study scope. The system representation at seams will be  
 435 reflective of expected facilities and arrangements that are consistent with the SPP futures being  
 436 modeled. All of the ties within the SPP footprint will be modeled based on historical data. This  
 437 historical data will be the most recent year available.

438  
 439  
 440  
 441

442 **D. Modeling Methods**

443 **1. Model Development**

444

445 As described in the sections below, the models used in the 20-Year Assessment are developed  
 446 based on information accumulated from various sources. The model building process starts  
 447 with a package utilizing publicly available data. The economic model is then reviewed  
 448 members. In addition, the powerflow model is imported into the economic model so that the  
 449 transmission topology is up-to-date. Other parts of the model development include adding a  
 450 generation expansion plan (resource planning) and developing a list of constraints (constraint  
 451 selection).

452

453 **2. Security-Constrained Economic Dispatch**

454

455 The economic dispatch model will include stakeholder-vetted data. Unit cost related data such  
 456 as costs and heat rates will be taken from publically available sources. Other data about the  
 457 physical characteristics of generators that are not related to costs and heat rates will be  
 458 reviewed and updated as needed by the members to provide company-specific values. These  
 459 data will be used to produce the security-constrained economic dispatch (SCED) solution. The  
 460 SCED solution requires dual optimization processes.

461

462 The first process is the security constrained unit commitment (SCUC). Here, the least cost  
 463 combination of units is determined subject to unit-specific operational constraints (e.g., ramping,  
 464 minimum output, min/max runtime, etc.), and some critical location-specific transmission  
 465 reliability constraints (e.g., must-run operational limits); but without explicit consideration of  
 466 transmission grid operational costs.

467

468 The second process is the security constrained economic dispatch (SCED) solution of the units  
 469 determined by the SCUC process. Here, the units are dispatched in a least-cost manner  
 470 subject to various transmission operational constraints (e.g., line thermal limits, voltage support,  
 471 etc.) and transmission reliability constraints (e.g., n- contingencies) to produce an overall least  
 472 cost solution for regional load.

473

474 Data about the physical characteristics of generators, which are not related to costs and heat  
 475 rates, will be reviewed and updated as needed by the members to provide company-specific  
 476 values.

477

478 **3. Power System Model for the economic dispatch model**

479

480 The powerflow used in the 20-Year Assessment will be the latest MDWG model as approved by  
 481 the TWG. Approved STEP projects as well as other special projects which are known by SPP

Deleted: Flow



483 staff (i.e. Entergy, AECI projects or those at other seams) will be added to the latest MDWG  
 484 model as of the beginning of the study. This powerflow will be uploaded into the economic  
 485 dispatch model.

486  
 487 Typical dynamic models for projected generation will be used for the 20-Year Assessment in  
 488 those scenarios in which steady state power transfers indicate minimal stability margins.

Comment [rah5]: P. Hassink suggested language

Comment [rah6]: Dan Lenihan suggest rewording

489 **4. Resource Planning Data**

490 The resource planning data will be vetted by stakeholders to ensure that the modeling of  
 491 stakeholder’s generation capacity is accurate. The stakeholders will have the opportunity to  
 492 update their data to ensure an accurate model.  
 493

494 **5. Constraint Selection**

495 The current NERC Book of Flowgates will be used as an initial list of constraints. Throughout  
 496 the analysis SPP will define additional constraints which will be vetted and approved by the  
 497 TWG.  
 498

499 Using a transmission analysis tool, SPP staff will identify additional constraints which should be  
 500 monitored in the economic dispatch model. The nature of the economic study tools is such that  
 501 the constraints are the only tool in the model which controls the flow on the transmission lines –  
 502 without the constraints there is no adherence to the line or transformer limits, etc. This is an  
 503 iterative process which will look for the next constraint. For the purposes of this analysis N-1  
 504 and a few select PTDF interface constraints will be selected in order to control the flow in key  
 505 transmission corridors. Not every flow will always be mitigated for every hour. Overloads can  
 506 occur. The constraints are selected by performing an N-1 contingency analysis on all hours of  
 507 the study year. All 300 kV and higher voltage facilities will be outaged; all 100 kV and higher  
 508 voltage facilities in SPP will be monitored.  
 509

Deleted: 345-

Deleted: 15-

513 **E. Twenty-Year ITP Assessment Process**

515 **1. Resource Planning**

516 Language to be added by Black & Veatch.  
 517

518 **2. Screening Analysis**

519 SPP will start the screening analysis using prototypes which are developed based on previous  
 520 EHV plans. These prototypes will be reviewed by stakeholders who have an opportunity to  
 521 review the prototypes and offer feedback in their design. SPP will analyze a wide variety of  
 522 possible transmission projects which have been identified by staff or suggested by stakeholders.  
 523 The purpose of the screening analysis is to identify the grouping of projects which meet the  
 524 goals of the future cost-effectively.  
 525

526 **3. Security Constrained Unit Commitment and Economic Dispatch Analysis**

527

530 SPP staff will use a security constrained economic dispatch software for the economic and unit  
 531 commitment analysis. The model will solve using nodal LMPs which will dispatch the  
 532 generation economically based unit characteristics, load information, and transmission  
 533 constraints.

534 **4. Limited Reliability Assessment**

535 SPP staff will perform a limited reliability assessment to help identify the additional reliability  
 536 issues and issues that the ITP projects may cause, in order to provide the most cost-effective,  
 537 versatile backbone. The purpose of this assessment is to test the robustness of the  
 538 transmission system and is not intended to be a test for NERC Reliability Standards  
 539 requirements<sup>6</sup>.

540 At present, a year 20 powerflow model has not been developed. Due to the lack of an available  
 541 AC model, a year 10/11 powerflow model will be substituted as a proxy for the year 20 model so  
 542 that both voltage and thermal concerns can be evaluated. In order to be sure that the various  
 543 futures and year 20 load levels are considered, analysis will also be performed on the year 20  
 544 cases.

545 In order to assess reliability from multiple aspects, the limited reliability assessment will be  
 546 divided into two portions. The first portion will be performed on the year 20 economic model,  
 547 simulating the 20 year load levels and dispatch. The analysis will consist of a DC (thermal)  
 548 contingency analysis, with and without the identified transmission plans, monitoring the 100 kV  
 549 and above system while considering 300 kV and above contingencies.

550 The second portion of the analysis will be performed on a year 10/11 powerflow model,  
 551 establishing a more thorough reliability evaluation of the 100 kV and above system. This  
 552 analysis will consist of an AC (thermal and voltage) contingency analysis, with and without the  
 553 identified transmission plans. SPP will monitor 100 kV and above facilities while considering  
 554 100 kV and above contingencies. In this analysis mitigation plans will be developed for all  
 555 violations. Additionally, a transfer capability (FCITC) will be performed on the year 10/11  
 556 powerflow model, with and without the identified transmission plans.

557 Scenarios in which steady state power transfers indicate minimal stability margins, a screening  
 558 stability study will be used to determine stability limits that would be applied to the Security  
 559 Constrained Unit Commitment and Economic Dispatch Analysis.

560 Those issues within SPP that are not addressed in this assessment will be passed to the 10-  
 561 Year Assessment for further evaluation. Based on the results of these analyses, the EHV  
 562 designs will be refined from a reliability perspective.

570 **5. Solution Development**

571 During the process of the 20-Year Assessment, SPP staff will review issues that are identified  
 572 during the various phases of the study. Those issues may include: thermal overloads, voltage  
 573 violations, constraint congestion, LMP variation and trapped generation. Staff will present these  
 574 issues to stakeholders and ask for feedback on EHV solutions to those issues. Those proposed  
 575 solutions will then be evaluated through a screening process to determine which solution sets  
 576

<sup>6</sup> Adherence to NERC Reliability Standards will continue to be checked through a separate NERC Reliability Compliance Assessment.

Deleted: on the proposed ITP projects

Deleted: that

Deleted:

Comment [rah7]: Rachel- suggested reword of sentence:  
 SPP staff will perform a limited reliability assessment to help identify the impact the 20-Year transmission plans may have upon system reliability, in order to provide the most cost-effective, versatile backbone.

Deleted: strictly

Deleted: ¶

Comment [rah8]: Do we want to leave in?

Comment [rah9]: P. Hassink suggested language

Comment [jbh10]: From Doug K: In various places, "345kV+" shows up, sometimes without the notation EHV. Especially when just "345kV+" is noted, it is not clear as to whether the manual means "345kV and above", or if it means "above 345kV". It is further confused by SPP's use (in different documents) of EHV to mean it one way and in others the other way. And the power industry appears to use the EHV term for Above 345kV. I think in the manual here we mean to include 345kV. So I would recommend dropping the use of EHV and clearly stating what we mean in these places as ""345kV and above".

582 work best. The solution sets (or portfolios) that result from the screening process will be further  
 583 developed and refined through more detailed analysis which will include evaluation of benefit  
 584 metrics as described in Section III.G of this manual.

585  
 586

## 587 **F. Valuation**

588

589 The ESWG through its work with the Metrics Task Force (MTF) created the Metrics for 20-Year  
 590 ITP Document. The document includes a description on the metrics proposed to measure both  
 591 cost-effectiveness and robustness. The metric descriptions below have been taken from the  
 592 Metrics document which was approved by the ESWG and MOPC.

### 593 **1. Cost-Effective: Individual Futures**

594 I. Minimization of the total costs (transmission capacity, generation capacity and  
 595 APC) that meet the requirements of a specified future and;

- 596 ○ Includes emissions costs
- 597 ○ May include different fuel prices for different futures.
- 598 ○ Includes all the costs for EHV transmission
  - 599 ■ The gathering systems would be developed during the ITP 10
  - 600 year plan (gathering systems have voltages less than 345kV).
- 601 ○ Includes an evaluation of whether or not a renewable energy standard or carbon  
 602 cap standard is met
  - 603 ■ If not met, then add either transmission or generation capacity, whichever  
 604 is lower cost. For example:
    - 605 ● For transmission capacity, increasing voltage
    - 606 ● For generation capacity, increasing wind capacity
- 607 ○ Includes an evaluation of adjusted production costs for alternative  
 608 generation/transmission combinations that meet the future's target.
- 609 ○ Includes an evaluation on the cost of generation capacity depending on location  
 610 (i.e. high wind zones vs low wind zones).

611 II. Would include comparative costs from various sources

- 612 ○ Real losses of energy
- 613 ○ Reserve margins
- 614 ○ Do not include changes in exports or imports in specified futures,<sup>7</sup> i.e. fix the  
 615 import/export levels in the model to a historical level OR benchmark hurdle rates  
 616 to peg SPP imports/exports at a historical level<sup>8</sup>. The study report shall clearly  
 617 point out this limitation in assumption and describe how the results may be  
 618 affected by it, e.g., what if the wind development to the north of SPP is  
 619 considerably different (higher) than modeled, resulting in higher transfers through  
 620 north SPP.

621

622 III. Additional factors to consider in individual futures:

- 623 ○ There are attributes of the transmission plans that may be evaluated in addition  
 624 to lowest cost – to be provided later.

<sup>7</sup> There is some value in the imports/exports. However, under SPC direction the impact of changes on the transmission system from imports/exports in the SPP region is being limited.

<sup>8</sup> SPP staff should provide an example of the two options.

- 625 ○ Interconnection of new generation to target location (collection stations will be
- 626 addressed in the 10 year plan)
- 627     ▪ Some locations may be ideal for wind, gas, coal, nuclear, etc.
- 628 ○ Interconnect new generation (GI process facilitation)
- 629     ▪ The EHV will target locations based on GI clusters and load which would
- 630 add additional value.
- 631     ▪ Targeting location of EHV based on access for desirable application
- 632     ▪ Alternative View - Might fall into the “collector system” context which
- 633 would be evaluated more in the 10 year ITP when looking at lower
- 634 voltage, therefore it should be a 10 year ITP metric.
- 635
- 636

Comment [jbh11]: Rework into paragraph form

## 637 2. Flexibility: Meeting Multiple Futures

### 638 I. Multiple Futures

- 639 • Projects that show up multiple times as cost effective for each future make for cost
- 640 effective planning.
- 641     ○ Interconnections at target locations which show up in multiple futures will have
- 642 greater weight.
- 643 • There is a weighting aspect that needs to be developed for ESWG and SPC
- 644 consideration. This may include identifying different plans per future. The futures will be
- 645 weighted by stakeholder determination.
- 646 • Cost effective solutions for individual futures may need to be modified in order to find a
- 647 cost effective solution for multiple futures
- 648 • Additional factors to consider in multiple futures
- 649     ○ Improved interconnection of new generation
- 650     ○ Dispersion vs concentration of generation resources and the cost impact under
- 651 different futures (i.e. wind)
- 652     ○ Alignment of projects with plans external to the SPP region in accordance with
- 653 FERC Order 890

### 654 II. Approach 1: Scenario Analysis

- 655 • Requires assignment of weights to various futures as noted above
- 656 • Requires running all futures against various transmission/generation plans
- 657     ○ The transmission plans being evaluated for multiple futures will meet the
- 658 requirements of each of the futures;
- 659     Or
- 660     ○ If not, must include an estimated cost for not meeting those requirements.
- 661     ○ These estimated costs must be documented along with rationale for subsequent
- 662 changes.
- 663 • Evaluates various transmission plans in terms of the transmission plan that has the
- 664 highest weighting for the lowest costs.
- 665

### 666 III. Approach 2: Contingency Analysis

- 667 • **This is not an N-1 AC analysis. This is an adaptive process to calculate a value of**
- 668 **the ITP in financial terms.**
- 669 • Overall plan is based on the future having the highest weight; i.e., the agreed upon
- 670 **expected** future.

- 671 ○ Requires a determination of which upgrades are built first (before the
- 672 uncertainties are resolved); i.e., would include portions of the transmission
- 673 system that are required for multiple futures
- 674 ○ Requires a process by which designs can be changed in the event that the
- 675 **expected** future does not come to fruition – contingency plans to go with the plan
- 676 designed to meet the expected future.
- 677 • Can include the use of weights in the evaluation of having to change the plan when
- 678 futures that are not expected occur.
- 679 ○ Can evaluate transition costs in terms of a comparison to the costs incurred had
- 680 the system been built to meet the alternative future.
- 681 ○ Various alternatives can be evaluated using this same measure and compared
- 682 on an expected value basis; i.e.,
- 683 **(Wgt\*Cost of plan) + Σ<sub>j</sub>(Wgts\*Transition costs of alternative futures)<sub>j</sub>**
- 684

685 **3. Robustness Metrics (will be updated as ESWG reviews the CRA results)**

- 686 I. Captures added value not previously quantified/qualified in SPP’s traditional
- 687 planning methods.
- 688 a) Improvements in reliability (value of improving the ability to keep the lights on)
- 689 ○ Value of delaying or advancing previously approved reliability projects
- 690 ○ Other values such as a backstop to a catastrophic event.
- 691 ○ Value of improved available transfer capability
- 692 b) Provides additional information to be considered in the siting of new generation
- 693 capacity
- 694 ○ Locating transmission in proximity to:
- 695 ■ Better wind locations
- 696 ■ Concentration of natural gas lines
- 697 ■ Water availability
- 698 ■ Rail access
- 699 ■ Lignite or coal resources
- 700 ■ Solar sites
- 701 ■ Highways
- 702 ■ Load centers, substations sites
- 703 ■ Environmentally sensitive areas
- 704 ■ Existing corridors
- 705 c) Losses not captured by APC such as generation losses due to curtailment.
- 706 ○ The value of an increase or decrease in transmission line losses are captured
- 707 in APC.
- 708 ○ The amount of additional or reduced energy due to a change in losses will be
- 709 reported separately from amount embedded in the APC.
- 710 d) Increased effective capacity factors
- 711 ○ Capacity factor improvement of resources between the base and change
- 712 cases, the capacity factor may change due to a reduction in congestion.
- 713 ○ Measures the benefit of adding transmission to reduce congestion on
- 714 curtailed resources.
- 715 e) Ability to reduce cost of capacity held in reserve for regulation<sup>9</sup>
- 716 ○ The nodal security constrained economic dispatch software may not be the
- 717 correct tool for this metric.

<sup>9</sup> Currently unable to define.

- 718 ○ Will focus more on hourly or five minute support and not planning or
- 719 operating reserves. More focus placed on spinning reserve and ACE.
- 720 f) Positive impact on capacity losses
- 721 ○ Reduced capacity that can be reflected in reduced losses and the possible
- 722 reduction in capacity margins.
- 723 ○ This metric will be used to capture a value for the capacity which may no
- 724 longer be required due to a reduction in losses and capacity margin.
- 725
  
- 726 II. Levelization of LMPs
- 727 • This could be indicative of the value of transmission in providing access to economical
- 728 sources of generation measured by the standard deviation in LMP price across the SPP
- 729 footprint.
- 730 • Formula could be based on what the SPP Markets group uses in the Monthly State of
- 731 the Market Report
  
- 732 III. Improved access to economical resources participating in SPP Markets
- 733 • Qualitative and quantitative based on quantitative metrics such as APC, volatility,
- 734 increased sales, etc.
- 735 • Assesses the value of the, now 187 and possibly more, commercial paths where
- 736 capacity increases and the average rate of the increase with additional transmission.
- 737 • Can be measured retroactively by calculating the number of new participants in the
- 738 Market by Market Monitoring efforts.
  
- 739 IV. Change in operating reserves
- 740 • Calculation of reserves before and after transmission projects (MW x \$/MW
- 741 implementation cost)
- 742 • Loss of Load Probability (LLP) studies will show the reduced requirements.
- 743 • Use Gas CT as base construction
- 744 • Evaluation of the regulation and following reserves needed for wind resources
- 745 • Reduction in need for reserve zones
  
- 746 V. TLR Reduction – Enabling Market Solutions
- 747 • This should be a subset analysis that would not be a full 8760 hr analysis. This analysis
- 748 could be limited to a subset of days or hours.
- 749 • Capture the value of fewer transmission loading reliefs during specific durations of the
- 750 year.
- 751 • The valuation will be based on a review of historical and projected data.
  
- 752 VI. Limited export/import improvements
- 753 • Will capture the effects on both the generation and the load.
- 754 • Need to consider the requirements under FERC Order 890 but not specifically use the
- 755 import/exports capabilities for valuing the transmission projects in the ITP. Multi-region
- 756 studies should capture the issues related to what is needed for import/export capability
- 757 under Order 890. Surplus wind exports would be handled under multi-regional studies.
  
- 758 VII. Improved economic market dynamics not measured in the security constrained
- 759 economic dispatch model.
- 760 • Can be used to look at constrained areas



- 761           o Does an increase in robustness eliminate, to a degree, the need for Narrowly
- 762            Constrained Areas as defined by MISO?
- 763           • This metric will be used to capture the value of eliminating load or congestion pockets
- 764            due to the reduction of redispatch.
- 765
  
- 766 VIII. Improved economic market dynamics measured in the nodal security constrained
- 767           economic dispatch model
- 768           • Value added by the change in average marginal cost. Determine if the cost of the next
- 769            marginal MW increased or decreased due to the addition of the transmission project.
- 770           • Marginal cost is defined as the cost of the marginal unit
- 771           • Has the cost of the next marginal MW increased or decreased by adding the additional
- 772            transmission project?
- 773           • Averaged over either an on or off peak period or a full 8760 analysis as determined by
- 774            SPP staff
  
- 775 IX. Reduction in market price volatility
- 776           • This relates to volatility over time and not geographic volatility
- 777           • Hedging tools will be reduced in value with less price
- 778           • Without stochastic analysis this metric is difficult to capture.
- 779           • The stochastic analysis would require a significant amount of computer time.
  
- 780 X. Reduction of emission rates and values
- 781           • CO<sub>2</sub>, NO<sub>x</sub>, SO<sub>2</sub>, values will be input into the model, thereby capturing the impact to the
- 782            dispatch and the APC.
- 783           • Currently the application for mercury is not well defined; however the units of mercury
- 784            emissions will be captured. Reducing pounds/tons of mercury has different values to
- 785            different market participants.
  
- 786 XI. Transmission corridor utilization
- 787           • How to efficiently utilize the ROW
- 788           • Must also consider the environmental impacts of the transmission.
  
- 789 XII. Ability to reduce cycling of base load units
- 790           • Excessive cycling increases maintenance costs of units requiring capital investment.
- 791           • New transmission that would impact this cycling would provide a value to the generation.
- 792           • Cycling is defined as a unit ramping up and down within its minimum and maximum.
- 793           • The number of cycles is determined by counting the number of times a unit's output
- 794            crosses the average operating level.
- 795           • The BA or TO will determine what is considered "normal" and "excess" cycling.
- 796           • This metric will apply to coal and nuclear plants which are 350MW and larger.
  
- 797 XIII. Generation Resource Diversity
- 798           • Fuel diversity adds fuel adjustment rate stability.
  
- 799 XIV. Ability to serve unexpected new load
- 800           • Results could be captured when you have unexpected extreme load growth.
- 801           • Transfer X% of additional energy to a load pocket with low impact on LMPs.
- 802           • Test the robustness by shifting load from one major load center to another.

803 XV. Part of Overall EHV Overlay Plan

- 804 • There is some value if the interim projects solve an immediate problem and can be  
805 incorporated into the long term comprehensive EHV Plan.  
806

807

808 **G. Deliverable**

809

810 **1. Finalize Solution**

811

812 Prior to developing the final set of projects, SPP staff expects to have a transmission plan  
813 developed for each future. Those multiple plans will be analyzed to determine which projects or  
814 combination of projects would be beneficial in all futures. The results of this analysis will be a  
815 single transmission plan (composed of multiple 345 kV+ projects) that is robust, being adaptable  
816 for all of the futures considered, and adding greater incremental value than incremental cost.  
817

818 **2. Report**

819 The deliverable for the 20-Year analysis will be a single transmission including staging and  
820 timing considerations to convey the appropriate order of implementation. The results of the  
821 analysis will be included in the 20-Year ITP Report.  
822

823

824 **IV. Ten-Year Integrated Transmission Planning**

825 The process for the 10-Year Assessment has not yet been developed. Once the process  
826 development has been completed this section of the manual will be updated to include that  
827 process.  
828

829 **A. Purpose**

830 Add Text

831

832 **B. Futures Evaluation**

833 Add Text

834

835 **C. Data Requirements**

836 Add Text

837

838 **1. Confidentiality of Data**

839 In addition to the treatment with respect to reporting requirements in Section 2.6, in all other  
840 activities SPP Staff will take all reasonable efforts to preserve the confidentiality of information in  
841 accordance with the provisions of the SPP Tariff (i.e., Sections 17.2(iv) and 18.2(vii);  
842 Attachment V (Section 13.1 and Article 22 of Appendix 6); Exhibit 1 (Section 2.3);  
843 Attachment AJ (Section 8); and Attachment C-One (Clause 7)).  
844



845 **2. Generating Unit Modeling Data**

846 Add Text  
847

848 **3. Reliability/Must-Run Conditions**

849 Add Text  
850

851 **4. Wind Farms**

852 Add Text  
853

854 **5. Interaction with ERCOT & WECC**

855 Add Text regarding DC Ties

856 **6. Stakeholder Review of Modeling Assumptions**

857 Add Text regarding DC Ties  
858  
859

860 **D. Assumptions**

861

862 **1. Load Forecast Assumptions**

863 Add Text  
864

865 **2. Fuel Prices**

866 Add Text  
867

868 **3. Emission Prices**

869 Add Text  
870

871 **4. Modeling Footprint**

872 Add Text  
873

874 **5. Import/Export Limits**

875 Add Text  
876  
877

878 **E. Modeling Methods**

879 Add Text

880 **1. Power Flow/Security-Constrained Economic Dispatch**

881 Add Text  
882

883 **2. Flowgate Definition**

884 Add Text

885

886

887 **F. Ten-Year ITP Process**

888 Add Text

889 Typical dynamic models for projected generation will be used for the 10-Year Assessment in  
890 those scenarios in which steady state power transfers indicate minimal stability margins.

Comment [rah12]: P. Hassink suggested language

891

892 **1. Model Development**

893 Add Text

894 **2. Flowgate Selection**

895 Add Text

896 **3. Screening Analysis**

897 Add Text

898 **4. Additional Flowgate Analysis**

899 Add Text

900 **5. Security Constrained Unit Commitment and Economic Dispatch Analysis**

901 Add Text

902 **6. PSS®E MUST Commercial Path Analysis**

903 Add Text

904 **7. Transfer Capability Analysis**

905 Add Text

906 Scenarios in which steady state power transfers indicate minimal stability margins, a screening  
907 stability study will be used to determine stability limits that would be applied to the Security  
908 Constrained Unit Commitment and Economic Dispatch Analysis.

Deleted: Eastward

Comment [rah13]: P. Hassink suggested language

909 **8. Solution Development**

910 Add Text

911

912

913 **G. Calculation of Benefits**

914 Add Text

915

916 **1. Cost-Effective Planning**

917 Add Text

918

919

920

921 **H. Deliverable**

922 Add Text

924 **1. Finalize Solution**

925 **Add Text**

926  
927  
928

929 **V. Near-Term Integrated Transmission Planning**

930 The third phase of the ITP process is the annual Near-Term assessment, which will be  
931 performed annually on a rolling window to be defined in the ITP study scope document. This  
932 assessment will analyze the Transmission System for solutions according to NERC Reliability  
933 Standards while incorporating individual Transmission Owner planning requirements. The  
934 assumptions for this assessment will be narrowed further than those for the 20-Year and 10-  
935 Year Assessments. This narrower focus is intended to ensure continuous adherence to NERC  
936 Reliability Standards while allowing the ITP process as a whole to focus on the creation of a  
937 Transmission System that meets the ITP planning principles.

939  
940 **A. Purpose**

941 The ITP Near-Term assessment determines the SPP upgrades required to meet reliability in the  
942 near term, including those upgrades recommended to the SPP BOD to receive an NTC.  
943

944  
945 **B. 20-Year and 10-Year ITP Interaction**

946 The ITP 20-Year and 10-Year plans will be incorporated into the Near-Term assessment  
947 annually. The plans will serve as part of a pool of solutions from which the Near-Term plans are  
948 developed to determine the best regional solution for the SPP footprint. There will also be  
949 interaction of the plans based on issued ATPs and NTCs.  
950

951  
952  
953 **C. Data Requirements**

954 Any entity that is subject to the NERC Reliability Standards is required to provide data to the  
955 Transmission Provider in accordance the NERC Reliability Standards for Modeling, Data and  
956 Analysis (the "NERC MOD Standards").

957  
958 When an entity is in the conceptual planning stages of new facilities that impact the  
959 interconnected operation of the Transmission System, it shall contact the Transmission Provider  
960 so that the optimal integration of any new facilities and potentially benefiting parties can be  
961 identified.  
962

963 In preparation for the annual update of transmission planning models for each annual planning  
964 cycle, SPP Members, Transmission Customers and other stakeholders must provide to the  
965 Transmission Provider the data specified in Section VII of Attachment O of the OATT.  
966

967 During the course of the annual planning cycle, if material changes to the data occur, the data  
968 owners must provide timely written notice to the Transmission Provider.  
969  
970

Deleted: t  
Deleted: p  
Comment [rah14]: research

973 Instructions to access modeling information are posted on the SPP website.<sup>10</sup>  
 974

975 **1. Confidentiality of Data**

976 In addition to the treatment with respect to reporting requirements in Section 2.6, in all other  
 977 activities SPP Staff will take all reasonable efforts to preserve the confidentiality of information in  
 978 accordance with the provisions of the SPP Tariff (i.e., Sections 17.2(iv) and 18.2(vii);  
 979 Attachment V (Section 13.1 and Article 22 of Appendix 6); Exhibit 1 (Section 2.3);  
 980 Attachment AJ (Section 8); and Attachment C-One (Clause 7)).  
 981  
 982  
 983  
 984

985 **D. Assumptions**

986 The Near-Term assessment will be performed on an annual basis. The study will be performed  
 987 on a shorter planning horizon than the 10-Year assessment and will focus on the reliability of  
 988 the system. The Near-Term assessment will take the following into account:  
 989  
 990

- 991 • NERC Reliability Standards;
- 992 • SPP Criteria;
- 993 • Transmission Owner-specific planning criteria as set forth in Section II of Attachment O;
- 994 • Previously identified and approved transmission projects;
- 995 • Zonal Reliability Upgrades developed by Transmission Owners, including those that  
 996 have their own FERC approved local planning process, to meet local area reliability  
 997 criteria;
- 998 • Long-term firm Transmission Service;
  - 999 ○ Accommodate and reflect the specific long-term firm transmission service requests  
 1000 of the Transmission Customers and specific interconnections of Generation  
 1001 Interconnection Customers no later than when the relevant Service Agreements  
 1002 and interconnection agreements are accepted by the Commission.
- 1003 • Load forecasts, including the impact on load of existing and planned demand  
 1004 management programs, exclusive of demand response resources;  
 1005 management programs, exclusive of demand response resources;
- 1006 • Capacity forecasts, including generation additions and retirements;
- 1007 • Existing and planned demand response resources; and
- 1008 • In developing the long term capacity forecasts, the studies will reflect generation and  
 1009 demand response resources capable of providing any of the functions assessed in the  
 1010 SPP planning process, and can be relied upon on a long-term basis. Such demand  
 1011 response resources shall be permitted to participate in the planning process on a  
 1012 comparable basis to the service provided by comparable generation resources where  
 1013 appropriate.  
 1014

1015 **1. MDWG Modeling**

1016 Staff will use the SPP Model Development Working Group (MDWG) models as a starting point  
 1017 for the ITP NT analysis. The MDWG creates new models annually and updates these models  
 1018 throughout the year.  
 1019

---


<sup>10</sup> <http://www.spp.org/section.asp?pageID=108>

1020  
1021  
1022  
1023  
1024  
1025  
1026  
1027  
1028  
1029  
1030  
1031  
1032  
1033

**E. Near-Term ITP Process**

Planning within SPP is a collaborative process with Transmission Owners, users, and other stakeholders. This Near-Term assessment process requires that Transmission Owners continue to develop expansion plans to meet the needs of their systems. At the same time, SPP assesses its system for the ability to meet applicable reliability standards and address stakeholder concerns, including those of regulators.

The 12-month Near-Term planning process focuses on the system’s reliability needs and the commercial and market needs for all the stakeholders in the SPP footprint. This process was developed by SPP staff in conjunction with the TWG. The process is shown in the figure below.



1034  
1035

1036 Details regarding key assumptions, models, project data, specific tasks, outstanding issues,  
 1037 progress reports, maps, and study results are available on the SPP web site.

1038  
 1039 The SPP Planning Process is open and participatory process. The process is designed to be  
 1040 transparent so all stakeholders have the opportunity to have input in the transmission plans  
 1041 recommended by SPP. Following are the key components of the ITPNT process:

- 1042 • The TWG meetings are open meetings, available for all stakeholders to attend. Not all  
 1043 stakeholders are allowed to vote, but they are allowed to take part in the discussion.  
 1044 TWG has the oversight of the Near-Term assessment, which includes approving the  
 1045 scope. Throughout the process the TWG is involved in the assessment progress. As  
 1046 part of the STEP report, the Near-Term assessment portion is reviewed by TWG before  
 1047 going to the Market Operations Policy Committee (MOPC).
  - 1048 ○ TWG updates MOPC of the assessment's progress. MOPC reviews the STEP  
 1049 report before it goes to SPP BOD for approval. Stakeholders are allowed to  
 1050 provide comments during these meetings.
- 1051 • Planning Summits (See section VII for more details)
- 1052 • Sub-regional Planning Meetings
  - 1053 ○ The purpose of the sub-regional area planning meetings is to identify  
 1054 unresolved local stakeholder issues and transmission solutions at a more  
 1055 granular level than can be accomplished at general regional planning meetings.  
 1056 The sub-regional planning meetings shall provide stakeholders with local needs  
 1057 the opportunity to provide advice and recommendations to the Transmission  
 1058 Provider and to the Transmission Owners.

1059 **1. Model Development Process**

1060 Model building begins in January and starts with the SPP MDWG spring case topology of that  
 1061 same year of the study. Transmission owners and balancing authorities provide generation  
 1062 dispatch and load information for the years to be studied.

1063  
 1064 Transmission owners enter network changes into MOD at which time the type and status of the  
 1065 network upgrades is identified. The type and status of MOD projects identify into which SPP  
 1066 model set the network change will be entered. Appendix A of this manual provides the listing of  
 1067 the description of the types and status.

1068  
 1069 Included in the Near-Term assessment models are all topology changes that have a NTC from  
 1070 SPP except projects that have been requested to be removed from the base ITP NT models.  
 1071 These exceptions must go through a stakeholder review process as described below:

- 1072 1) Stakeholder requests NTC project be removed from the base ITP NT model along with  
 1073 the reason why they would like the project excluded and re-evaluated in the ITP NT.
- 1074 2) If SPP Tariff Study Group identifies any Transmission Service that may be dependent  
 1075 upon the project, SPP Planning Group would identify any concerns in connection with  
 1076 removing the project from the base model and re-evaluating the need
- 1077 3) The list of NTC projects to be re-evaluated is given to stakeholders for a 15 day review  
 1078 and comment window.

1079  
 1080 Generation interconnection facilities are included in the Near-Term assessment model if they  
 1081 have an executed Interconnection Agreement (IA) and not on suspension. Generation capacity  
 1082 does not get included in the assessment until there is an executed transmission service  
 1083 agreement. **Dynamic models of generators supplied through the interconnection process will be  
 1084 applied to the Near-Term Assessment stability analysis of cases 5-6 years into the future.**

Comment [rah15]: P. Hassink suggested language

1087  
 1088 Only long term firm transmission service is included in the assessment models with two  
 1089 exceptions: 1) included is service from new generation that has a high probability of going into  
 1090 service and also getting an executed transmission service agreement; 2) included are  
 1091 transactions to make generation and load match. If a planned generating resource does not  
 1092 have a TSR filed service agreement but does have both a high probability of going into service  
 1093 and a high probability of obtaining an executed transmission service agreement, that new  
 1094 generator's service can be included in the SPP regional reliability planning models if it meets all  
 1095 of the following requirements:

- 1096 ○ A formal request has been sent to SPP requesting the generation capacity be
- 1097 included into the ITP;
- 1098 ○ The generating resource has a FERC-filed IA not on suspension or FERC-filed
- 1099 interim IA;
- 1100 ○ The generating resource has acquired the funding for major equipment;
- 1101 ○ The generating resource has entered the Aggregate Study or equivalent;
- 1102 Transmission Owner transmission service study publicly posted on OASIS and
- 1103 has a completed facility study that is waiting for final results without unmitigated
- 1104 third party impacts<sup>11</sup>;
- 1105 ○ The generating resource has acquired air and environmental permits where
- 1106 applicable;
- 1107 ○ The generating resource has started construction with major equipment
- 1108 procurement contracts awarded; and
- 1109 ○ The generating resource's unit(s) must be dispatchable and committable.

1110  
 1111  
 1112 In later years of the Near-Term assessment analysis when there is a shortfall between  
 1113 interchange, generation, and load, the following process will be used to address generation  
 1114 deficiencies<sup>12</sup>:

- 1115 1) Exhaust the customer's dispatchable designated network resources until the network
- 1116 resources are sufficient to meet network load.
- 1117 a. Dispatch generation by using dispatch orders provided by the transmission
- 1118 planning personnel of the SPP Transmission Owners and by representatives of
- 1119 the transmission service customers.
- 1120 b. Add generation from behind the meter generating units. This generation consists
- 1121 of dispatchable behind the meter generation that may not already included in the
- 1122 SPP MDWG models.
- 1123 2) If the customer's dispatchable designated load cannot be served after Step One, then
- 1124 exhaust the customer's other dispatchable, operational generation that is not
- 1125 designated.
- 1126 a. Dispatch generation by using dispatch orders provided by the transmission
- 1127 planning personnel of the SPP Transmission Owners and by representatives of
- 1128 the transmission service customers.
- 1129 b. Add generation from behind the meter generating units. This generation consists
- 1130 of behind the meter generation that may not already included in the SPP MDWG
- 1131 models.

Comment [rah16]: Didn't add language about the exceptions to these rules. Can add language:

- If a generator does not meet all the above requirements, a request can be made to TWG on a case by case basis. TWG will take into account the following additional points:
- An exception to include service from generation that will defer transmission expenditure(s) without a TSR filed service agreement and without a filed IA or a filed interim IA that have a high probability of going into service and also getting both an executed IA and an executed transmission service agreement must meet all of the below requirements:
- A formal request has been sent to SPP requesting the generation capacity be included into the STEP. The request should identify which transmission upgrades will be deferred
- The generating resource has a mitigation plan for the deferred transmission upgrades until it makes a financial commitment to perform the upgrades
- A Definitive Interconnection System Impact Study Agreement for the generating resource has been executed, an interim IA has been requested when the DISIS was posted and a final IA was FERC filed when applicable
- An RFP for the generating resource has been awarded, if applicable

<sup>11</sup> Eliminates generators that may drop out as a result of changes in study results

<sup>12</sup> Non-dispatchable wind generation or other generation with operating restrictions or forecasted projections shall not be used.



1136  
1137  
1138  
1139  
1140  
1141  
1142  
1143  
1144  
1145  
1146  
1147  
1148  
1149  
1150  
1151  
1152  
1153  
1154  
1155  
1156  
1157  
1158  
1159  
1160  
1161  
1162  
1163  
1164  
1165  
1166  
1167  
1168  
1169

- 3) If the customer's designated load cannot be served after Step One and Step Two, exhaust the Host Transmission Owner's existing dispatchable generation.
  - a. Dispatch generation by using dispatch orders provided by the transmission planning personnel of the SPP Transmission Owners and by representatives of the transmission service customers.
- 4) If the customer's network load cannot be served after the above steps, exhaust Independent Power Producer's ("IPP") existing dispatchable generation in the Host Transmission Owner's modeling area.
  - a. Exhaust IPP generation on a pro rata, as available basis accounting for firm transmission commitments. In other words, Use power from each IPP to meet the customer's designated load. The amount of power from each IPP will be determined using the total amounts available based on the IPP's historical generating levels minus the amount of power to model existing transmission service from the IPP.
- 5) Finally, if a customer's network load cannot be served after applying the above steps, exhaust existing primary modeling area dispatchable generation with includes IPP's existing generation and existing primary modeling area generation.
  - a. Similar to Step Four, exhaust this generation on a pro rata, as available basis for firm transmission commitments. The amount of power from each IPP and from each primary modeling area generation will be determined using the total amounts available based on the maximum generating levels minus the amount of power to model existing transmission service from the IPP and primary modeling area generation.

SPP uses scenarios to evaluate reliability. The number of scenarios is determined each year and approved by the TWG.

Below is a flow chart of SPP planning modeling process.


Deleted: ¶

Deleted: ¶  
Exhaust the dispatchable generation of the network customer, ¶  
Exhaust the Independent Power Producers (IPP) dispatchable generation in the same model area, ¶  
Dispatch the remaining unused, dispatchable generation on a pro rata basis within SPP footprint.¶



# SPP Planning Modeling Process

August 2010



## 2. Inter-Regional Coordination

SPP is responsible for coordinating transmission planning with each neighboring interconnected system. SPP will coordinate any activities and studies based on the agreements listed in Addendum 1 to Attachment O of the OATT. As part of the inter-regional coordination process, SPP will share system plans with neighboring entities and identify system enhancements on the seams.

## 3. Transmission Operating Guides

SPP uses Transmission Operating Guides in its Near-Term Assessment analysis. Appendix B of this manual contains the SPP procedure to address use of operating guides in planning studies.

## 4. Assessment Methodology

Each year the assessment's scope is developed and approved by the TWG. The scope will contain following:

- The years and seasons to be modeled
- Treatment of upgrades in the models
- Scenario cases to be evaluated
- Description of the contingency analysis and monitored facilities
- Any new special conditions that are modeled or evaluated for the study
- **Stability analysis will be performed using models 5-6 years into the future**

Comment [rah17]: P. Hassink suggested language

## 5. Solution Development

After SPP performs the reliability assessment identifying the bulk power problems, SPP will present and solicit Transmission Owners and stakeholders for transmission solutions to those reliability problems. SPP solicits stakeholders in several forums including the planning summits and working group meetings. After receiving feedback from stakeholders, SPP will take current Aggregate Studies and Generation Interconnection studies into consideration to develop and validate the best regional solution for problems. Then SPP shares the proposed solutions with the members and stakeholders at various stakeholder meetings asking for additional feedback on the solutions. This process repeats for several iterations as staff refines the solutions in a set timeline.

Throughout the process, alternative solutions are proposed by stakeholders. SPP analyzes those alternatives in accordance with Section III.8 of Attachment O of the OATT.

## F. Deliverable

The deliverable for the Near-Term Assessment will be a list of 69 kV+ projects that would maintain the reliability of the SPP Region in the near term horizon.

In developing the annual STEP report, staff will include a section about the annual Near-Term Assessment. This section will summarize the regional, sub-regional and local transmission needs of the SPP Region in the near term horizon which is assessed to meet SPP's reliability needs. The Near-Term Assessment results will also contain a list of at least the following upgrades:

- Regional upgrades required to maintain reliability in accordance with the NERC Reliability Standards and SPP Criteria in the near term horizon;

- Zonal upgrades required to maintain reliability in accordance with more stringent individual Transmission Owner planning criteria in the near term horizon; and
- Inter-regional upgrades developed with neighboring Transmission Providers to meet inter-regional needs, including results from the coordinated system plans, in the near term horizon.

### 1. Finalize Solution

Throughout the Near-Term Assessment process, SPP shares, discusses, and refines proposed solutions with stakeholders. The solutions are finalized in the annual STEP report.

## VI. Issuance of NTCs and ATPs

Once the ITP is reviewed by the MOPC and approved by the BOD, staff will issue NTC letters for approved projects in the 20-Year, 10-Year, and Near-Term Assessments which are within the financial window as approved by the BOD. The NTC is sent to the incumbent Transmission Owner(s) for the project. All other projects approved by the BOD in the ITP will receive an Authorization to Plan (ATP). All of the projects for which an ATP is issued will be posted on the SPP website.

Deleted: which will serve as notification that the project has an ATP

## VII. Reporting Requirements

Staff will inform the appropriate working groups throughout the year of the progress of the ITP assessments. SPP will also report on these assessments in its annual STEP report which will include a list of projects from those assessments. The STEP report will be presented to the MOPC and the BOD for approval.

### A. Stakeholder Review Process

To show transparency in its planning processes, SPP holds planning summits that allow stakeholders opportunity to engage in, develop, and review SPP's on-going planning assessments and their results. SPP also has working groups meetings as another forum for stakeholders to become involved in SPP planning studies.

## VIII. Ongoing Economic Modeling & Methods Process

### A. Interaction with Other SPP Data & Modeling Activities

The transmission network models applied to transmission project/upgrade economic analyses are derived from underlying seasonal power flow cases as constructed and managed by the SPP Model Development Working Group ("MDWG"). SPP has developed specific procedures for converting underlying MDWG power flow cases for interface with the simulation models applied for network economic analyses.

For efficiency of activities within SPP, the same or similar transmission network models and simulation models are also applied to other market simulation and analysis activities within the SPP organization.

DRAFT



## Appendix A

Type	Status	Description	MDWG	STEP/ Tariff	Special Study
TSR	w/NTC (Approved)	Projects identified through Aggregate Study with an executed Transmission Service Agreement and an issued Notice To Construct	X	X	X
	Proposed (No NTC)	Proposed projects that do not have an NTC			X
LGIP	w/GIP	Projects identified through the Large or Small Generator Interconnection Procedures (LGIP, SGIP) with an executed Large Generator Interconnection Agreement and not on suspension	X	X	X
	w/GIP on Suspension	Projects identified through the Large or Small Generator Interconnection Procedures (LGIP, SGIP) with an executed Large Generator Interconnection Agreement and on suspension			X
	No GIP	Projects <u>without</u> an executed Large or Small Generator Interconnection Agreement (LGIP, SGIP)			X
Reliability	STEP (w/NTC) or TO Planned	Appendix B Projects that have a Notice to Construct or Transmission Owner Planning Criteria with an issued Notice To Construct	X	X	X
	STEP Proposed (No NTC)	Appendix A Projects and projects that are being studied as part of the current STEP process, or are under consideration			X
	NERC Standard Compliance	Projects needed to comply with NERC Reliability Standards or SPP Criteria that are not part of STEP	X		X
Economic	Approved (Sponsored)	Projects identified through Attachment O identified that have been shown to provide regional economic benefit that have a contract that financially commits a Project Sponsor	X	X	X
	Approved (Not Sponsored)	Projects identified through Attachment O identified that have been shown to provide regional economic benefit that have no contract to build			X
Requested	Stakeholder Driven	Transmission upgrades, requested by a Transmission Customer or other entity, which do not meet the definition of any other category of Network Upgrades.	X		X
	Alternative	Projects that are alternatives to any TSR, STEP, or Economic Project. i.e. differed projects			
Network	Energized	Projects that are in-service from a previous MOD Type & Status. Constructed facilities that are in-service.	X	X	X
Network	Outage	Projects that change network topology status. Constructed facilities that are out-of-service or normally open.	X	X	X
Network	Update	Projects that updates network data	X	X	X

## Appendix B

### SPP Transmission Operating Guides Review Procedure

This procedure documents the process of how a Transmission Operating Guide (TOG) shall be included in the ITP and SPP Aggregate Transmission Service Studies (ATSS). In most cases TOGs are not intended to indefinitely defer needed Transmission System upgrades. Effective TOGs shall be utilized in all transmission tariff service functions and OATT planning processes.

For a TOG to be considered for use in the ITP and ATSS as a possible mitigation plan, it shall be on file with SPP. An effective TOG must state the system conditions under which the TOG is to be used and describe, in detail, the action the operators will take. The TOG must be signed by someone in charge of operations from the Transmission Owner or transmission operator submitting the TOG.

An effective TOG shall continue to be used in evaluation of the ITP and ATSS unless the facility-owning Transmission Owner or transmission operator withdraws the TOG. In cases where the TOG is withdrawn before the TOG becomes ineffective, any Transmission System Upgrades lie with the Transmission Owner.

A new TOG provided as interim mitigation for an SPP-required project shall automatically be withdrawn when the project is completed.

A TOG is considered an effective solution for facilities that are not listed in the TOG if, in the act of implementing the TOG for the elements listed, other overloads or voltage violations are corrected.

Service Upgrades associated with new Transmission Service Requests or Designated Resources that cause a TOG to be ineffective will be classified as Base Plan Upgrades in accordance with Attachment J.

Transmission System upgrades that become necessary because a TOG has been identified to be ineffective in order to maintain the reliability of the Transmission System shall be categorized as Reliability Upgrades, utilizing the procedures of Attachment O of the OATT.

The upgrade(s) proposed to address an ineffective TOG may work towards either eliminating the TOG or the ineffectiveness of the TOG.

### Effective TOGs

1. A TOG addressing Transmission System loading must include a short-term emergency rating which allows sufficient time to implement the TOG.
2. A TOG requiring generation redispatch must indicate if generator location is critical and, if so, must state in detail which units or plants will be re-dispatched. Absence of such specificity means location is not critical and generators may be selected from the fleet the entity has authority to run. The ramp rate of the generation must be capable of relieving the overload or voltage issue within the time allowed as specified in the TOG.
3. A TOG must not cause a violation elsewhere on the Transmission System.
4. A TOG addressing a voltage violation must provide for restoring minimum acceptable voltage conditions within a time frame so as not to cause permanent equipment damage.

A TOG shall identify the means by which system control is implemented. That is, if supervisory control is utilized it must so state.

DRAFT