

SPP-NTC-20125

SPP
Notification to Construct

February 14, 2011

Mr. Harold Wyble
Kansas City Power & Light Company
801-A, PO Box 418679
Kansas City, MO 64141-9679

RE: Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Wyble,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachment O, Section VI, of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing Kansas City Power & Light Company, as the Designated Transmission Owner, to construct the Network Upgrade(s).

On January 25, 2011, the Southwest Power Pool ("SPP") Board of Directors approved the Network Upgrade(s) listed below to be constructed.

Withdrawal of Upgrades

Previous NTC number: 20009

Previous NTC issue Date: 2/13/2008

Project ID: 417

Project Name: Line – Avondale- Gladstone 161 kV Ckt 1

Network Upgrade ID: 10543

Network Upgrade Description: Upgrade wave trap at Gladstone from 800 Amp to 1200 Amp.

Reason For Change: Model correction. Existing rating of wave trap is 1200 Amp.

Withdrawal of Network Upgrade


Kansas City Power & Light Company has been made aware of all Network Upgrades withdrawn through the expansion plan process. This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP within 90 days of the date of this NTC.

SPP-NTC-20125

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,



Lanny Nickell
Vice President, Engineering
Phone (501) 614-3232 • Fax: (501) 821-3198 • lnickell@spp.org

cc: Carl Monroe, Katherine Prewitt, Todd Fridley, Patricia Denny