

**SPP-NTC-200303**

**SPP  
Notification to Construct**

November 14, 2014

Mr. Noman Williams  
Mid-Kansas Electric Company  
301 W. 13th Street  
Hays, KS 67601

RE: Notification to Construct Approved High Priority Upgrades

Dear Mr. Williams,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachment O, Section VI, of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing Mid-Kansas Electric Company ("MKEC"), as the Designated Transmission Owner, as indicated below with regard to the following Network Upgrade(s).

On October 28, 2014, the SPP Board of Directors approved the Network Upgrades(s) listed below to be withdrawn.

**Withdrawal of Upgrades**

**Previous NTC Number:** 200275

**Previous NTC Issue Date:** 5/19/2014

**Project ID:** 30643

**Project Name:** Line - Coldwater Tap - Ashland - Clark Tap 115 kV Ckt 1

**Network Upgrade ID:** 50825

**Network Upgrade Name:** Ashland - Coldwater Tap 115 kV Ckt 1

**Network Upgrade Description:** Construct new 26-mile 115 kV line from Ashland to Coldwater Tap with a rating of 160 MVA.

**Reason for Change:** Updated load projections no longer show a need for the project.

**Network Upgrade ID:** 50826

**Network Upgrade Name:** Ashland - Clark Tap 115 kV Ckt 1 (MKEC)

**Network Upgrade Description:** Construct MKEC's portion of new 24-mile 115 kV line from Ashland to Clark Tap (ITCGP) with a rating of 160 MVA.

**Reason for Change:** Updated load projections no longer show a need for the project.

**SPP-NTC-200303**

**Previous NTC Number:** 200275

**Previous NTC Issue Date:** 5/19/2014

**Project ID:** 30734

**Project Name:** Line - Coldwater - Coldwater Tap - Shooting Star Wind 115 kV Ckt 1

**Network Upgrade ID:** 50997

**Network Upgrade Name:** Coldwater Tap - Shooting Star Wind 115 kV Ckt 1

**Network Upgrade Description:** Construct new 26-mile 115 kV line from Coldwater Tap to Shooting Star Wind.

**Reason for Change:** Current load projections no longer show a need for the project.

**Network Upgrade ID:** 50998

**Network Upgrade Name:** Coldwater - Coldwater Tap 115 kV Ckt 1

**Network Upgrade Description:** Construct new 5.5-mile 115 kV line from Coldwater to Coldwater Tap.

**Reason for Change:** Updated load projections no longer show a need for the project.

**Withdrawal of Network Upgrade**

This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,



Lanny Nickell

Vice President, Engineering

Phone: (501) 614-3232 • Fax: (501) 482-2022 • [lnickell@spp.org](mailto:lnickell@spp.org)

cc: Carl Monroe - SPP  
Antoine Lucas - SPP  
Tom Hestermann - MKEC  
Clarence Suppes - MKEC  
Al Tamimi - MKEC