

SPP-NTC-200304

**iSPP
Notification to Construct**

November 14, 2014

Mr. Clarence Suppes
Mid-Kansas Electric Company
301 W. 13th Street
Hays, KS 67601

RE: Notification to Construct Approved High Priority Upgrades

Dear Mr. Suppes,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachment O, Section VI, of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing Mid-Kansas Electric Company ("MKEC"), as the Designated Transmission Owner, as indicated below with regard to the following Network Upgrade(s).

On October 28, 2014, the SPP Board of Directors approved the Network Upgrades(s) listed below to be withdrawn.

Withdrawal of Upgrades

Previous NTC Number: 200276

Previous NTC Issue Date: 5/19/2014

Project ID: 30733

Project Name: Line - Sun City - Sun South 115 kV Ckt 1

Network Upgrade ID: 50996

Network Upgrade Name: Sun City - Sun South 115 kV Ckt 1

Network Upgrade Description: Construct new 12.5-mile 115 kV line from Sun City to Sun South.

Reason for Change: Updated load projections no longer show a need for the project.

Previous NTC Number: 200276

Previous NTC Issue Date: 5/19/2014

SPP-NTC-200304

Project ID: 30735

Project Name: Line - Clark Tap - Minneola 115 kV Ckt 1

Network Upgrade ID: 50999

Network Upgrade Name: Clark Tap - Minneola 115 kV Ckt 1 (MKEC)

Network Upgrade Description: Construct MKEC's portion of new 7.5-mile 115 kV line from Clark Tap (ITCGP) to Minneola.

Reason for Change: Updated load projections no longer show a need for the project.

Previous NTC Number: 200276

Previous NTC Issue Date: 5/19/2014

Project ID: 30773

Project Name: Sub - Milton 138 kV

Network Upgrade ID: 51054

Network Upgrade Name: Milton 138 kV Substation

Network Upgrade Description: Tap existing 115 kV line from Harper to Milan Tap to construct new Milton substation.

Reason for Change: Updated load projections no longer show a need for the project.

Withdrawal of Network Upgrade

This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,

A handwritten signature in black ink that reads "Lanny Nickell".

Lanny Nickell

Vice President, Engineering

Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

cc: Carl Monroe - SPP
Antoine Lucas - SPP
Tom Hestermann - MKEC

SPP-NTC-200304

Al Tamimi - MKEC