

SPP-NTC-200312

**iSPP
Notification to Construct**

January 5, 2015

Ms. Kristine Schmidt
ITC Great Plains, LLC
3500 SW Fairlawn Road
Topeka, KS 66614

RE: Notification to Construct Approved High Priority Upgrades

Dear Ms. Schmidt,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachment O, Section VI, of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing ITC Great Plains, LLC ("ITCGP"), as the Designated Transmission Owner, as indicated below with regard to the following Network Upgrade(s).

On October 28, 2014, the SPP Board of Directors approved the Network Upgrade(s) listed below to be withdrawn.

Withdrawal of Upgrades

Previous NTC Number: 200274
Previous NTC Issue Date: 5/19/2014
Project ID: 30826
Project Name: XFR - Clark Co. 345/115 kV Transformer

Network Upgrade ID: 51056
Network Upgrade Name: Clark Co. 345/115 kV Ckt 1 Transformer
Network Upgrade Description: Install new 345/115 kV transformer at Clark Co. substation. Install any necessary 115 kV terminal equipment.
Reason for Change: Updated load projections no longer show a need for the project.

Network Upgrade ID: 51057
Network Upgrade Name: Clark Co. 345 kV Ckt 1 Terminal Upgrades
Network Upgrade Description: Install any necessary 345 kV terminal equipment at Clark Co. associated with new 345/115 kV transformer.
Reason for Change: Updated load projections no longer show a need for the project.

SPP-NTC-200312

Withdrawal of Network Upgrade

This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,



Lanny Nickell
Vice President, Engineering
Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

cc: Carl Monroe - SPP
Antoine Lucas - SPP
Alan Myers - ITCGP