

SPP-NTC-200307

**SPP
Notification to Construct**

January 23, 2015

Mr. Mohamad Doghman
Omaha Public Power District
444 South 16th Street Mall
Omaha, NE 68102

RE: Notification to Construct for Transmission Service Request resulting from Aggregate Transmission Service Study SPP-2013-AG1-AFS-7

Dear Mr. Doghman,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachment O, Section VI, of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing Omaha Public Power District ("OPPD"), as the Designated Transmission Owner, to construct the Network Upgrades.

On September 29, 2014, SPP concluded that the project(s) is required on the OPPD system to fulfill Transmission Service Requests as detailed in Aggregate Facility Study SPP-2013-AG1-AFS-7.

New Network Upgrades

Project ID: 30839

Project Name: Multi - S906 - S912 69 kV Accelerate

Estimated Cost for Project: \$63,389 (this project cost contains Network Upgrades not included in this NTC)

Network Upgrade ID: 51127

Network Upgrade Name: S906 South - S924 69 kV Ckt 1 Rebuild Accelerate

Network Upgrade Description: Accelerate the rebuild of 1.34-mile 69 kV line from S906 to S924 to achieve a new emergency rating of 143 MVA.

Network Upgrade Owner: OPPD

Categorization: Transmission Service

Network Upgrade Specification: All elements and conductor must have at least an emergency rating of 143 MVA.

SPP-NTC-200307

Network Upgrade Justification: SPP-2013-AG1-AFS-7
Need Date for Network Upgrade: 6/1/2018
Estimated In-Service Date: 6/1/2018
Estimated Cost for Network Upgrade (current day dollars): \$60,300
Cost Allocation of the Network Upgrade: Base Plan
Estimated Cost Source: SPP
Date of Estimated Cost: 9/29/2014

Network Upgrade ID: 51128
Network Upgrade Name: S924 - S912 69 kV Ckt 1 Terminal Upgrades Accelerate
Network Upgrade Description: Accelerate the installation of terminal upgrades at S924 to increase emergency rating of S924 - S912 69 kV Ckt 1 to 99 MVA.
Network Upgrade Owner: OPPD
Categorization: Transmission Service
Network Upgrade Specification: All elements and conductor must have at least an emergency rating of 99 MVA.
Network Upgrade Justification: SPP-2013-AG1-AFS-7
Need Date for Network Upgrade: 6/1/2018
Estimated In-Service Date: 6/1/2018
Estimated Cost for Network Upgrade (current day dollars): \$3,089
Cost Allocation of the Network Upgrade: Base Plan
Estimated Cost Source: SPP
Date of Estimated Cost: 9/29/2014

Commitment to Construct

Please provide to SPP a written commitment to construct the Network Upgrade(s) within 90 days of the date of this Notification to Construct, pursuant to Attachment O, Section VI.6 of the SPP OATT, in addition to providing a construction schedule and an updated $\pm 20\%$ cost estimate, NTC Project Estimate, in the Standardized Cost Estimate Reporting Template for the Network Upgrade(s). Failure to provide a written commitment to construct as required by Attachment O could result in the Network Upgrade(s) being assigned to another entity.

Mitigation Plan

The Estimated In-Service Date represents the timing required for the Network Upgrade(s) to address the identified need. Your prompt attention is required for formulation and approval of any necessary mitigation plans for the Network Upgrade(s) included in the Network Upgrades(s) if the Estimated In-Service Date is not feasible. Additionally, if it is anticipated that the completion of any Network Upgrade will be delayed past the Estimated In-Service Date, SPP requires a mitigation plan be filed within 60 days of determination of expected delays.

Notification of Commercial Operation

SPP-NTC-200307

Please submit a notification of commercial operation for each listed Network Upgrade to SPP as soon as the Network Upgrade is complete and in-service. Please provide SPP with the actual costs of these Network Upgrades as soon as possible after completion of construction. This will facilitate the timely billing by SPP based on actual costs.

Notification of Progress

On an ongoing basis, please keep SPP advised of any inability on OPPD's part to complete the approved Network Upgrade(s). For project tracking, SPP requires OPPD to submit status updates of the Network Upgrade(s) quarterly in conjunction with the SPP Board of Directors meetings. However consistent with Section 20.1 and 32.10 of the SPP OATT, OPPD shall also advise SPP of any inability to comply with the project(s) Schedule as the inability becomes apparent.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this project(s) and nothing in this letter shall carry such terms and conditions.

Don't hesitate to contact me if you have questions or comments about these requests. Thank you for the important role that you plan in maintaining the reliability of our electric grid.

Sincerely,

A handwritten signature in black ink that reads "Lanny Nickell".

Lanny Nickell
Vice President, Engineering
Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

cc: Carl Monroe - SPP
Antoine Lucas - SPP
James Foley - OPPD
Dan Lenihan - OPPD