

**SPP-NTC-200355**

**SPP  
Notification to Construct**

November 3, 2015

Mr. John Fulton  
Southwestern Public Service Company  
P.O. Box 1261  
Amarillo, TX 79105

RE: Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Fulton,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachments O and Y of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") to Southwestern Public Service Company ("SPS"), as the Designated Transmission Owner, as indicated below with regard to the following Network Upgrade(s).

On October 27, 2015, the SPP Board of Directors approved the Network Upgrade(s) listed below to be withdrawn.

**Withdrawal of Upgrades**

**Previous NTC Number:** 200332

**Previous NTC Issue Date:** 2/18/2015

**Project ID:** 30842

**Project Name:** Line - Martin - Pantex North - Pantex South - Highland Park 115 kV Ckt 1 Reconductor

**Network Upgrade ID:** 51138

**Network Upgrade Name:** Pantex North - Pantex South 115 kV Ckt 1 Reconductor

**Network Upgrade Description:** Reconductor 3.4-mile 115 kV line from Pantex North to Pantex South.

**Reason for Change:** SPP determined the Network Upgrade was no longer required in the 2016 ITP Near-Term Assessment.

**Network Upgrade ID:** 51141

**Network Upgrade Name:** Highland Park - Pantex South 115 kV Ckt 1 Reconductor

**SPP-NTC-200355**

**Network Upgrade Description:** Reconductor 6.8-mile 115 kV line from Highland Park Tap to Pantex South. Replace wave trap at Pantex South. Replace switch at Highland Park Tap.

**Reason for Change:** SPP determined the Network Upgrade was no longer required in the 2016 ITP Near-Term Assessment.

**Network Upgrade ID:** 51142

**Network Upgrade Name:** Martin - Pantex North 115 kV Ckt 1 Reconductor

**Network Upgrade Description:** Reconductor 5.1-mile 115 kV line from Martin to Pantex North. Replace wave trap at Pantex North.

**Reason for Change:** SPP determined the Network Upgrade was no longer required in the 2016 ITP Near-Term Assessment.


**Withdrawal of Network Upgrade**

This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,

A handwritten signature in black ink that reads "Lanny Nickell".

Lanny Nickell  
Vice President, Engineering  
Phone: (501) 614-3232 • Fax: (501) 482-2022 • [lnickell@spp.org](mailto:lnickell@spp.org)

cc: Carl Monroe - SPP  
Antoine Lucas - SPP  
William Grant - SPS