

SPP-NTC-200372

**SPP
Notification to Construct**

February 12, 2016

Mr. Shawn Robinson
American Electric Power
212 E. 6th St.
Tulsa, OK 74119

RE: Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Robinson,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachments O and Y of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") to American Electric Power ("AEP") as agent for Public Service Company of Oklahoma, Southwestern Electric Power Company, and AEP Oklahoma Transmission Company, as the Designated Transmission Owner, as indicated below with regard to the following Network Upgrade(s).

On January 26, 2016, the SPP Board of Directors approved the Network Upgrade(s) listed below to be withdrawn.

Withdrawal of Upgrades

Previous NTC Number: 200314

Previous NTC Issue Date: 2/18/2015

Project ID: 30803

Project Name: Line - Mineola - Grand Saline 69 kV Ckt 1 Rebuild

Network Upgrade ID: 51089

Network Upgrade Name: Mineola - Grand Saline 69 kV Ckt 1 Rebuild

Network Upgrade Description: Rebuild Grand Saline - Mineola 69 kV line, and upgrade jumpers, switches, CTs, and relay settings at both substations.

Reason for Change: SPP determined the Network Upgrade was no longer required in the 2016 ITP Near-Term Assessment.

Previous NTC Number: 200327

Previous NTC Issue Date: 2/18/2015

SPP-NTC-200372

Project ID: 30847

Project Name: Line - South Shreveport - Wallace Lake 138 kV Ckt 1 Rebuild

Network Upgrade ID: 51144

Network Upgrade Name: South Shreveport - Wallace Lake 138 kV Ckt 1 Rebuild

Network Upgrade Description: Rebuild 11.2-mile 138 kV line from South Shreveport to Wallace Lake. Upgrade wavetraps and conductor at South Shreveport.

Reason for Change: SPP determined the Network Upgrade was no longer required in the 2016 ITP Near-Term Assessment.

Withdrawal of Network Upgrade

This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,

A handwritten signature in black ink that reads "Lanny Nickell".

Lanny Nickell

Vice President, Engineering

Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

- cc: Carl Monroe - SPP
Antoine Lucas - SPP
Bob Bradish - AEP
Paul Johnson - AEP
Richard Ross - AEP
Brian Johnson - AEP
Scott Rainbolt - AEP
Matt McGee - AEP