

**SPP-NTC-200443**

**SPP  
Notification to Construct**

February 22, 2017

Mr. Jeff Tullis  
Grand River Dam Authority  
P.O. Box 1128  
Pryor, OK 74119

RE: Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Tullis,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachments O and Y of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing Grand River Dam Authority ("GRDA"), as the Designated Transmission Owner, to construct the Network Upgrade(s).

On January 31, 2017, the SPP Board of Directors approved the Network Upgrade(s) listed below to be constructed.

**Withdrawal of Upgrades**

**Previous NTC Number:** 200390  
**Previous NTC Issue Date:** 5/17/2016  
**Project ID:** 30892  
**Project Name:** Sub - CPPXF#22 69 kV Terminal Upgrades

**Network Upgrade ID:** 51212  
**Network Upgrade Name:** CPPXF#22 69 kV Terminal Upgrades  
**Network Upgrade Description:** Upgrade breaker and relay(s) at CPPXF#22 69 kV substation.  
**Reason for Change:** SPP determined the Network Upgrade was no longer required in the 2017 ITPNT.

**Previous NTC Number:** 200390  
**Previous NTC Issue Date:** 5/17/2016  
**Project ID:** 30909  
**Project Name:** Sub - Collinsville - Skiatook 69 kV Terminal Upgrades

**SPP-NTC-200443**

**Network Upgrade ID:** 51230

**Network Upgrade Name:** Collinsville - Skiatook 69 kV Terminal Upgrades

**Network Upgrade Description:** Replace CTs and relays at both Collinsville and Skiatook substations to increase the rating of the 69 kV line from Collinsville to Skiatook. Upgrade breaker at Collinsville.

**Reason for Change:** SPP determined the Network Upgrade was no longer required in the 2017 ITPNT.

**Withdrawal of Network Upgrade**

GRDA has been made aware of all Network Upgrades withdrawn through the expansion plan process. This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,

A handwritten signature in black ink that reads "Lanny Nickell".

Lanny Nickell

Vice President, Engineering

Phone: (501) 614-3232 • Fax: (501) 482-2022 • [lnickell@spp.org](mailto:lnickell@spp.org)

cc: Carl Monroe - SPP  
Antoine Lucas - SPP  
Jay Caspary - SPP  
Mike Stafford - GRDA  
Joe Fultz - GRDA