

SPP
Notification to Construct

June 28, 2018

Mr. Jeff Tullis
Grand River Dam Authority
P.O. Box 1128
Pryor, OK 74119

RE: Withdrawal of Notification to Construct for Transmission Service Request resulting from Aggregate Transmission Service Study SPP-2014-AG1-AFS-6

Dear Mr. Tullis,

Southwest Power Pool, Inc. ("SPP") provides this withdrawal of a Notification to Construct ("NTC") to Grand River Dam Authority ("GRDA").

On June 7, 2018, SPP concluded that the Network Upgrade listed below should be withdrawn and informed the Project Cost Working Group of the withdrawal on June 12, 2018, per SPP Business Practice 7060 Section 7.1.

Withdrawal of Upgrades

Previous NTC Number: 200380

Previous NTC Issue Date: 4/20/2016

Project ID: 30984

Project Name: Sub - Claremore 69 kV Terminal Upgrades

Network Upgrade ID: 51392

Network Upgrade Name: Claremore 161 kV Ckt 1 Terminal Upgrades

Network Upgrade Description: Install 161 kV ring bus at Claremore substation to increase the rating of the Claremore 161/69 kV Ckt 1 Transformer.

Reason for Change: GRDA informed SPP that an alternate solution at a reduced cost could be implemented to achieve the required rating.

Network Upgrade ID: 51393

Network Upgrade Name: Claremore 69 kV Terminal Upgrades

Network Upgrade Description: Replace 69 kV switches at Claremore substation to increase the rating of the Claremore 161/69 kV Ckt 1 Transformer and Claremore 161/69 kV Ckt 2 Transformer.

Reason for Change: GRDA informed SPP that an alternate solution at a reduced cost could be implemented to achieve the required rating.

SPP-NTC-210488

Withdrawal of Network Upgrade

GRDA has been made aware of all Network Upgrade(s) withdrawn through the expansion plan process. This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this project(s) and nothing in this letter shall change such terms and conditions.

Don't hesitate to contact me if you have questions or comments about these requests. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,

A handwritten signature in black ink that reads "Lanny Nickell".

Lanny Nickell

Vice President, Engineering

Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

cc: Carl Monroe - SPP
Antoine Lucas - SPP
Jay Caspary - SPP
Stace Kegley - GRDA
Joe Fultz - GRDA
Tim Brown - GRDA