

**SPP-NTC-210518**

**iSPP  
Notification to Construct**

June 21, 2019

Mr. Jarred Cooley  
Southwestern Public Service Company  
790 S Buchanan Street  
Amarillo, TX 79101

RE: Withdrawal of Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Cooley,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachments O and Y of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing Southwestern Public Service Company ("SPS"), as the Designated Transmission Owner, to construct the Network Upgrade(s).

On April 30, 2019, the SPP Board of Directors approved the withdrawal of the Network Upgrades listed below. Per SPP Business Practice 7060 Section 7.1, SPP will inform the Transmission Working Group, Project Cost Working Group, and Markets and Operations Policy Committee of the withdrawal.

**Withdrawal of Upgrades**

**Previous NTC Number:** 200333

**Previous NTC Issue Date:** 2/18/2015

**Project ID:** 30578

**Project Name:** Multi - Bailey Co. - Lamb Co. 115 kV

**Network Upgrade ID:** 50725

**Network Upgrade Name:** Bailey Co. - Bailey Co. Pump 115 kV Ckt 1

**Network Upgrade Description:** Build new 9.4-mile 115 kV line from Bailey Co. to Bailey Co. Pump. Install any necessary terminal equipment at Bailey Co.

**Reason for Change:** SPP determined the Network Upgrade was no longer required

**Network Upgrade ID:** 50729

**Network Upgrade Name:** Bailey Co. Pump - Sundan Rural 115 kV Ckt 1

**Network Upgrade Description:** Build new 11.7-mile 115 kV line from Bailey Co.

Pump to Sundan Rural and convert high side voltage of the distribution transformers at

**SPP-NTC-210518**

Bailey Co. Pump and Sudan Rural from 69 kV to 115 kV.

**Reason for Change:** SPP determined the Network Upgrade was no longer required

**Network Upgrade ID:** 50731

**Network Upgrade Name:** New Amherst 115/69 kV Ckt 1 Transformer

**Network Upgrade Description:** Install new 115/69 kV 84 MVA transformer at New Amherst. Install any necessary 69 kV terminal equipment.

**Reason for Change:** SPP determined the Network Upgrade was no longer required

**Network Upgrade ID:** 50732

**Network Upgrade Name:** New Amherst - Sudan Rural 115 kV Ckt 1

**Network Upgrade Description:** Build new 8.6-mile 115 kV line from New Amherst to Sudan Rural.

**Reason for Change:** SPP determined the Network Upgrade was no longer required

**Network Upgrade ID:** 50734

**Network Upgrade Name:** New Amherst 115 kV Terminal Upgrades Ckt 1

**Network Upgrade Description:** Install 115 kV terminal equipment at New Amherst to accommodate new 115/69 kV transformer.

**Reason for Change:** SPP determined the Network Upgrade was no longer required

**Network Upgrade ID:** 50735

**Network Upgrade Name:** Lamb Co. - New Amherst 115 kV Ckt 1

**Network Upgrade Description:** Build new 13.9-mile 115 kV line from Lamb Co. to New Amherst. Convert high side voltage of the West Littlefield distribution transformer from 69 kV to 115 kV.

**Reason for Change:** SPP determined the Network Upgrade was no longer required

**Previous NTC Number:** 200401

**Previous NTC Issue Date:** 5/25/2016

**Project ID:** 30578

**Project Name:** Multi - Bailey Co. - Lamb Co. 115 kV

**Network Upgrade ID:** 50736

**Network Upgrade Name:** West Littlefield - West Littlefield Tap 115 kV Ckt 1

**Network Upgrade Description:** Tap the existing 115 kV line from Lamb Co. to Plant X at a location approximately 0.6 miles to the west of the West Littlefield substation to construct new West Littlefield Tap substation. Install three-way switch at new West Littlefield Tap substation. Install new 0.6-mile 115 kV line from West Littlefield to new West Littlefield Tap substation.

**Reason for Change:** SPP determined the Network Upgrade was no longer required

**SPP-NTC-210518**


**Withdrawal of Network Upgrade**

SPS has been made aware of all Network Upgrades withdrawn through the expansion plan process. This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,

A handwritten signature in black ink that reads "Lanny Nickell".

Lanny Nickell

Vice President, Engineering

Phone: (501) 614-3232 • Fax: (501) 482-2022 • [lnickell@spp.org](mailto:lnickell@spp.org)

cc: Carl Monroe - SPP  
Antoine Lucas - SPP  
Jay Caspary - SPP  
William Grant - SPS