

SPP-NTC-210568**SPP
Notification to Construct**

November 12, 2020

Mr. Ryan Houk
Transource Missouri, LLC
1 Riverside Plaza, 25th Floor
Columbus, OH 43215

RE: Notification to Construct Approved Economic Network Upgrades

Dear Mr. Houk,

On October 29, 2019, the Southwest Power Pool, Inc. ("SPP") Board of Directors ("Board") approved the Network Upgrade listed below to be constructed as part of the 2019 Integrated Transmission Planning ("ITP") Assessment. The Network Upgrade was deemed to be a Competitive Upgrade in accordance with Section I of Attachment Y of the SPP Open Access Transmission Tariff ("OATT") which requires the selection of a Designated Transmission Owner ("DTO") through the Transmission Owner Selection Process ("TOSP") in Attachment Y of the SPP OATT. On October 27, 2020, the Board concluded the Transmission Owner Selection Process for the Network Upgrade by selecting Transource Missouri, LLC ("TSMO") as the DTO.

Accordingly, pursuant to Section 3.3 of the SPP Membership Agreement and Attachments O and Y of the SPP OATT, SPP provides this Notification to Construct ("NTC") directing TSMO, as the DTO, to construct the Network Upgrade.

New Network Upgrades**Project ID:** 81561**Project Name:** Multi - Sooner - Wekiwa 345 kV and Sand Springs - Sheffield 138 kV**Need Date for Project:** 1/1/2026**Estimated Cost for Project:** \$107,368,091 (this project cost contains Network Upgrades not included in this NTC)**Network Upgrade ID:** 112458**Network Upgrade Name:** Sooner - Wekiwa 345 kV New Line

SPP-NTC-210568

Network Upgrade Description: Build a new 345 kV line from Sooner to Wekiwa with a summer emergency rating of 1792 MVA

Network Upgrade Owner: TSMO

MOPC Representative(s): Not Applicable

TWG Representative: Not Applicable

Categorization: Economic

Network Upgrade Specification: All elements and conductor must have at least a minimum emergency rating of 1792 MVA, but are not limited to that amount.

Network Upgrade Justification: Upgrade identified in the 2019 ITP assessment as an economic project

Estimated Cost for Network Upgrade (current day dollars): \$97,111,851

Cost Allocation of the Network Upgrade: Base Plan

Estimated Cost Source: TSMO

Date of Estimated Cost: 6/3/2020

Commitment to Construct

In accordance with Section III of Attachment Y of the SPP OATT, in order to become the DTO for the Network Upgrade, TSMO must within seven (7) calendar days of receiving this NTC must (1) provide written notification to SPP that it accepts the NTC and (2) submit to SPP a deposit in accordance with Section III.2(d)(xii) of Attachment Y of the SPP OATT. TSMO shall be deemed to have waived its right to become the DTO if these requirements are not met.

By accepting the NTC, TSMO agrees that as the DTO selected by the Board through the TOSP, that TSMO will complete the Network Upgrade in accordance with the RFP Proposal submitted by TSMO in the TOSP for the Network Upgrade.

Notification of Commercial Operation

Please submit a notification of commercial operation for each listed Network Upgrade to SPP as soon as the Network Upgrade is complete and in-service. Please provide SPP with the actual costs of these Network Upgrades as soon as possible after completion of construction. This will facilitate the timely billing by SPP based on actual costs.

Notification of Progress

On an ongoing basis, please keep SPP advised of any inability on TSMO's part to complete the approved Network Upgrade(s). For project tracking, SPP requires TSMO to submit status updates of the Network Upgrade(s) quarterly in conjunction with the SPP Board of Directors meetings. However, TSMO shall also advise SPP of any inability to comply with the Project Schedule as soon as the inability becomes apparent.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to

SPP-NTC-210568

this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions.
Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,



Antoine Lucas
Vice President, Engineering
Phone: (501) 614-3382 • Fax: (501) 482-2022 • alucas@spp.org

cc: Lanny Nickell - SPP
Casey Cathey - SPP
David Kelley - SPP
Bethany McCrea - TSMO