

ACAP PRM – Informational

	Summer	Winter	Formula
[A] Total LRE Forecasted Peak Demand	57,885	48,211	
[B] Base PRM	16%	36%	
[C] Base PRM Required Capacity	67,147	65,567	[A] * (1+[B])
[D] Performance Based Accreditation (PBA – EFORd) Impact	5,535	7,111	
[E] Fuel Assurance Incremental Outage Impact (IOI)	N/A	4,102	
[F] Total PBA and Fuel Assurance Impact	5,535	11,213	[D] + [E]
[G] ACAP PRM	6.44%	12.74%	$([C] - [F] - [A]) / [A]$
[H] EFOF Adjuster	N/A	61.29%	[E] / [I]
[I] Total System Fuel Assurance (FA – EFOF) Impact	N/A	6,693	

For more information on the Performance Based Accreditation (PBA) and Fuel Assurance (FA) policies, please refer to [RR554](#) and [RR621](#), respectively.